CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING & INVESTIGATIONS DIVISION
BUILDING MATERIALS LISTING PROGRAM

LISTING SERVICE

LISTING No.:	1451-1332:0110
CATEGORY:	1451 - HEAD-OF-WALL/WALL-TO-WALL JOINT SYSTEMS
LISTEE:	SPECIFIED TECHNOLOGIES 210 Evans Way, Somerville, NJ, 08876 Contact: Vail, David (908) 526-8000 (908) 231-8415 Email: dvail@stifirestop.com
DESIGN:	SpecSeal® Firestop Spray: Latex Base (SpecSeal® AS Spray) and Silicone/Urethane Hybrid (SpecSeal® Fast Tack™ Spray). Refer to listee's product data sheet and UL Fire Resistance Directory for additional detailed product description and operational considerations.
RATING:	See Approval for rating
INSTALLATION:	In accordance with listee’s printed installation instructions, UL Fire Resistance Directory, applicable codes and ordinances and in a manner acceptable to the authority having jurisdiction.
MARKING:	Listee’s name, type identification and UL label.
APPROVAL:	Listed as ½-hour, 1-hour, 2-hour, 3-hour, 4-hour fire-rated firestop systems for construction joint firestop systems, perimeter fire containment firestop systems and through-penetration firestop systems when installed in accordance with the UL Fire Resistance Directory. Refer to UL Fire Resistance Directory for detailed information for the specific assembly. Construction Joint Firestop Systems: Nos. FF-D-0028, FF-D-1025, FW-D-1006, HWD-0043, HW-D-0044, HW-D-0086, HW-D-0088, HW-D-0099, HW-D-0137, HW-D-0140, HW-D-0252, HW-D-0377, HW-D-0548, HW-D-0617, HW-D-0642. HW-D-0645, HW-D-1034, WW-D-1090.Perimeter Fire Containment Firestop Systems: CW-D-1011, CW-D-2005, CW-D-2042, CW-D-2056, CW-S-0002, CW-S-0003, CW-S-1019, CW-S-2061, CW-S-2064, CW-S-2066.Through-Penetration Firestop Systems: C-AJ-1318, W-L-1208, F-A-1068.
NOTES:	

03-13-12 gt

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING & INVESTIGATIONS DIVISION
BUILDING MATERIALS LISTING PROGRAM

LISTING SERVICE

This listing is based upon technical data submitted by the applicant. OSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued: 03/24/2026

Listing Expires: 06/30/2027

Authorized By: **Michael Huang**, Program Coordinator
Fire Engineering & Investigations Division