## CITY OF NEW YORK DEPARIMENT OF BUILDINGS

Pursuant to Administrative Code Section 27-131, the following equipment or material has been found acceptable for use in accordance with the Report of the Material and Equipment Acceptance (MEA) Division.

## Rudolph J. Rinaldi, R.A., Commissioner

## MEA 28-92-M

Report of Material and Equipment Acceptance Division Manufacturer - Specified Technologies Inc., 200 Evans Way, Suite 2, Somerville, NJ 08876.

Product - Fill, void or cavity material for fire protection.

Pertinent Code Section - 27-345.

Prescribed Test - RS 5-19 (ASTM E814).

Laboratory - Underwriters Laboratories Inc.

Test report - File R14288, dated April 9, 1991, November 6, 1991, August 9, 1991, October 31, 1991, September 17, 1991.

Description - Fill, void or cavity material for thru-penetrations in fire-rated gypsum board wall construction or concrete wall/floor as specified in the particular systems. The SpecSeal Caulk Sealant material shall be applied in accordance with Underwriters Laboratories Inc. system number listed below in achieving the required fire resistance ratings.

Laboratory	System No.	Fire Protection Ratings (Hr) F T
UL	437	3 0
UL	438	3 0
UL	440	3 2(no cables)
UL	464	2 1-1/2
UL	465	2 0
UL	466	2 0
UL	467	2 0
UL	477	3 2
UL	479	3 0

Recommendation - That the above described fill, void or cavity material, used to fill the remaining voids in wall assemblies with the above described fire protection rating, where electrical trays, cables, mechanical piping or ductwork pass through the assembly, be accepted for use in such assemblies when installed in accordance with the manufacturer's application instructions. Suitable support angles and fasteners as required for respective assemblies shall be provided in accordance with manufacturer's recommendations. All shipments and deliveries of such materials shall be accompanied by a certificate or label certifying that the materials shipped or delivered are equivalent to those tested and acceptable for use, as provided for in Section 27-131 of the Building Code.

Final Acceptance DEC 04 1992
Examined by