

**CITY OF NEW YORK
DEPARTMENT OF BUILDINGS**

Pursuant to Administrative Code Section 27-131, the following equipment or material has been found acceptable for use in accordance with the Report of the Material and Equipment Acceptance (MEA) Division.

Gaston Silva, R.A., Commissioner
MEA 130-96-M

Report of Material and Equipment Acceptance Division

Manufacturer - Specified Technologies Inc., 200 Evans Way, Suite 2, Somerville, New Jersey 08876.

Trade Name - SpecSeal red wrap strip.

Product - Fill, Void or Cavity material for fire protection.

Pertinent Code Section(s) - 27-345.

Prescribed Test(s) - RS 5-19 (ASTM E814).

Laboratory - Underwriters Laboratories, Inc.

Test Report(s) - UL File 14288, dated June 14, 1993, August 18, 1995, August 19, 1995, September 1, 1995, September 20, 1995 and November 16, 1995.

Description - Fill, Void or Cavity material for thru-penetrations in fire-rated assembly as indicated below, is a highly intumescent, elastomeric strip for firestopping through penetrations in the opening and shall be applied in accordance with Underwriters Laboratories Inc. system numbers listed below in achieving the required fire resistance ratings.

Laboratory	UL System	F Rating	T Rating
U.L.	CAJ-1213	3 & 4	0
U.L.	CAJ-1214	3	0
U.L.	CAJ-1215	3 & 4	0
U.L.	CAJ-2092	3	3
U.L.	CAJ-2124	2 & 3	0 & 2
U.L.	CAJ-2125	3	3
U.L.	CAJ-2126	3	1 1/2 & 2
U.L.	CAJ-3085	3	1/2
U.L.	FC-2019	1 & 2	1 & 2
U.L.	FC-2022	1 & 2	1 & 2
U.L.	FC-2033	1	1
U.L.	FC-2034	1	1
U.L.	FC-2035	1	1
U.L.	FC-2036	1	1
U.L.	FC-2037	1	1
U.L.	FC-2044	1	1
U.L.	FC-8001	1 & 2	1 & 2
U.L.	WL-2059	1 & 2	1 & 1 1/2 & 2
U.L.	WL-2074	1 & 2	1 & 2

Recommendation - That the above described fill, void or cavity material, used by itself or in conjunction with other MEA accepted firestop materials to fill the remaining voids in wall or floor/ceiling assemblies with the above described fire protection rating, where there may or may not be electrical trays, cables, mechanical piping or ductwork pass through the assembly, be accepted for use in such assemblies when installed in accordance with the manufacturer's application instructions. Suitable support angles and fasteners are required for respective assemblies shall be provided in accordance with manufacturer's recommendations. All shipments and deliveries of such materials shall be accompanied by a certificate or label certifying that the materials shipped or delivered are equivalent to those tested and acceptable for use, as provided for in Section 27-131 of the Building Code.

Final Acceptance SEP 27 1996

Examined by S Derphidan