



**CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION  
 OFFICE OF THE STATE FIRE MARSHAL  
 FIRE ENGINEERING & INVESTIGATIONS DIVISION  
 BUILDING MATERIALS LISTING PROGRAM**

**LISTING SERVICE**

<b>LISTING No.:</b>	4485-1332:0500
<b>CATEGORY:</b>	4485 - OPENING PROTECTION (FIRESTOPPING)
<b>LISTEE:</b>	SPECIFIED TECHNOLOGIES 210 Evans Way, Somerville, NJ, 08876 Contact: Vail, David (908) 526-8000 (908) 231-8415 Email: <a href="mailto:dvail@stifirestop.com">dvail@stifirestop.com</a>
<b>DESIGN:</b>	Specified Technologies Inc., EZ PATH Retrofit Firestop Device Model EZDR400 and EZDR200. Model EZDR200 for use in conjunction with 2" diameter EMT, steel conduit or steel pipe sleeves. Model EZDR400 for use in conjunction with 4" diameter EMT, steel conduit or steel pipe sleeves. Each device consists of a galvanized steel housing with intumescent curtain sized to the specific diameter of the sleeve for compliance with UL System No.F-A-3063, F-A-3064, W-J-3240, and W-L-3435 Through Penetration Firestop Systems. Refer to listee's product data sheet and UL Fire Resistance Directory for additional detailed product description and operational considerations.
<b>RATING:</b>	F Rating - 1 and 2Hr  T Rating - 0, 1/4, 1/2, 1-1/4 & 2 Hr  L Rating 2 to 14 CFM (At Ambient Temperature)
<b>INSTALLATION:</b>	In accordance with listee's printed installation instructions, UL Fire Resistance Directory, applicable codes and ordinances and in a manner acceptable to the authority having jurisdiction.
<b>MARKING:</b>	Listee's name, type identification and UL label.
<b>APPROVAL:</b>	Listed as 1-hour, and 2-hour, fire-rated firestop systems for through-penetration firestop systems when installed in accordance with the UL Fire Resistance Directory. Refer to UL Fire Resistance Directory for detailed information for the specific assembly. UL System No.F-A-3063, F-A-3064, W-J-3240, and W-L-3435 Through Penetration Firestop Systems.
<b>NOTES:</b>	



**CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION  
OFFICE OF THE STATE FIRE MARSHAL  
FIRE ENGINEERING & INVESTIGATIONS DIVISION  
BUILDING MATERIALS LISTING PROGRAM**

**LISTING SERVICE**

10-09-2017 dcc



This listing is based upon technical data submitted by the applicant. OSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

**Date Issued: 03/28/2024**

**Listing Expires: 06/30/2025**

Authorized By: **David Castillo**, Program Coordinator  
Fire Engineering & Investigations Division