CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING & INVESTIGATIONS DIVISION
BUILDING MATERIALS LISTING PROGRAM

LISTING SERVICE

LISTING No.:	4485-1332:0500
CATEGORY:	4485 - OPENING PROTECTION (FIRESTOPPING)
LISTEE:	SPECIFIED TECHNOLOGIES 210 Evans Way, Somerville, NJ, 08876 Contact: Vail, David (908) 526-8000 (908) 231-8415 Email: dvail@stifirestop.com
DESIGN:	Specified Technologies Inc., EZ PATH Retrofit Firestop Device Model EZDR400 and EZDR200. Model EZDR200 for use in conjunction with 2" diameter EMT, steel conduit or steel pipe sleeves. Model EZDR400 for use in conjunction with 4" diameter EMT, steel conduit or steel pipe sleeves. Each device consists of a galvanized steel housing with intumescent curtain sized to the specific diameter of the sleeve for compliance with UL System No.F-A-3063, F-A-3064, W-J-3240, and W-L-3435 Through Penetration Firestop Systems. Refer to listee's product data sheet and UL Fire Resistance Directory for additional detailed product description and operational considerations.
RATING:	F Rating - 1 and 2Hr T Rating - 0, 1/4, 1/2, 1-1/4 & 2 Hr L Rating 2 to 14 CFM (At Ambient Temperature)
INSTALLATION:	In accordance with listee’s printed installation instructions, UL Fire Resistance Directory, applicable codes and ordinances and in a manner acceptable to the authority having jurisdiction.
MARKING:	Listee’s name, type identification and UL label.
APPROVAL:	Listed as 1-hour, and 2-hour, fire-rated firestop systems for through-penetration firestop systems when installed in accordance with the UL Fire Resistance Directory. Refer to UL Fire Resistance Directory for detailed information for the specific assembly. UL System No.F-A-3063, F-A-3064, W-J-3240, and W-L-3435 Through Penetration Firestop Systems.
NOTES:	

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING & INVESTIGATIONS DIVISION
BUILDING MATERIALS LISTING PROGRAM

LISTING SERVICE

10-09-2017 dcc

This listing is based upon technical data submitted by the applicant. OSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued: 03/24/2026

Listing Expires: 06/30/2027

Authorized By: **Michael Huang**, Program Coordinator
Fire Engineering & Investigations Division