

System Number	Rating	Description	Sheet Number
HEAD-OF-WALL JOINTS			
HW-D-0043	1, 2, 3 & 4 HR	GYPSUM WALL PERPENDICULAR TO DECK	SHEET 1
HW-D-0747	1 & 2 HR	GYPSUM WALL PARALLEL TO DECK, STEEL PLATE BRIDGING FLUTES	SHEET 1
HW-D-0210	1 & 2 HR	GYPSUM WALL PARALLEL TO DECK, DIRECTLY UNDER BOTTOM FLUTE	SHEET 1
HW-D-0365	1 & 2 HR	GYPSUM WALL PARALLEL TO DECK, PARTIALLY UNDER BOTTOM FLUTE	SHEET 1
HW-D-0252	1 & 2 HR	GYPSUM WALL UNDER STEEL BEAM	SHEET 2
HW-D-0517	1 & 2 HR	GYPSUM WALL OFFSET FROM STEEL BEAM	SHEET 2
HW-D-0548	1 & 2 HR	GYPSUM SHAFT WALL PERPENDICULAR TO DECK	SHEET 3
HW-D-0544	1 & 2 HR	GYPSUM SHAFT WALL PARALLEL TO DECK	SHEET 3
HW-D-0642	1 & 2 HR	GYPSUM SHAFT WALL UNDER STEEL BEAM	SHEET 4
HW-D-0645	1 & 2 HR	GYPSUM SHAFT WALL OFFSET FROM STEEL BEAM	SHEET 4
HW-D-0646	1 & 2 HR	GYPSUM SHAFT WALL AT EDGE OF SLAB (e.g. STAIRWELL)	SHEET 4
HW-D-0140	3 HR	CONCRETE/BLOCK WALL PARALLEL TO DECK	SHEET 5
HW-D-0086	1, 2, 3 & 4 HR	CONCRETE/BLOCK WALL PERPENDICULAR TO DECK	SHEET 5
BOTTOM-OF-WALL JOINTS			
BW-S-2003	1 & 2 HR	GYPSUM WALL - ES SEALANT	SHEET 5
BW-S-0017	1 & 2 HR	GYPSUM WALL - TRACK TOP GASKET	SHEET 5
BW-S-0020	1 & 2 HR	GYPSUM SHAFT WALL - ES SEALANT	SHEET 5
BW-S-0038	1 & 2 HR	GYPSUM SHAFT WALL - TRACK TOP GASKET	SHEET 5
FLOOR-TO-WALL JOINTS			
FW-D-1006	2 HR	CONCRETE FLOOR TO CONCRETE/BLOCK WALL - SPRAY	SHEET 5
FW-D-1007	3 HR	CONCRETE FLOOR TO CONCRETE/BLOCK WALL - SEALANT	SHEET 5
WALL-TO-WALL JOINTS			
WW-S-0052	1, 2, 3 & 4 HR	GYPSUM WALL TO CONCRETE/BLOCK WALL - SEALANT	SHEET 6
WW-S-0063	1 & 2 HR	GYPSUM WALL TO CONCRETE/BLOCK WALL - INTUMESCENT GASKET	SHEET 6
WW-S-0064	1 & 2 HR	SHAFT WALL TO CONCRETE/BLOCK WALL - INTUMESCENT GASKET	SHEET 6
WW-D-0004	3 HR	CONCRETE/BLOCK WALLS - MAX 1" JOINT - SEALANT	SHEET 6
WW-D-1006	2 HR	CONCRETE/BLOCK WALLS - MAX 4" JOINT - SPRAY	SHEET 6
WALL-TO-FIREPROOFED COLUMN			
STJ-F-120-01	2 HR	GYPSUM WALL TO COLUMN WEB - SPRAY & BACKING	SHEET 6
STJ-F-120-02	2 HR	GYPSUM WALL TO COLUMN FLANGE - SEALANT & BACKING	SHEET 6
PERIMETER FIRE BARRIER SYSTEMS			
CW-D-1041	2 HR	CURTAIN WALL - MIN 6" SILL HEIGHT - QUICK CLIP SYSTEM	SHEET 7
CW-D-1044	2 HR	CURTAIN WALL - STEEL BACKPAN, FLUSH SILL - FIRESTOP SPRAY	SHEET 7
CW-D-1051	2 HR	CURTAIN WALL - CONTINUOUS GLAZING (KISS MULLION), OPTIONAL RAISED FLOOR - QUICK CLIP SYSTEM	SHEET 7
STBPF-120-03	2 HR	CURTAIN WALL - ALL VISION GLASS, FLUSH SILL, SHADOW BOX - FIRESTOP SPRAY	SHEET 7
STBPF-120-04	2 HR	HYBRID WINDOW WALL - MULTIPLE CLOSURE PANEL OPTIONS - WINDOW WALL GASKET	SHEET 8
CW-S-1007	2 HR	STEEL STUD WALL - PLATFORM FRAMED, MULTIPLE FINISH OPTIONS - TRACK TOP GASKET	SHEET 8
CW-S-2076	2 HR	STEEL STUD WALL - BALLOON FRAMED, MULTIPLE FINISH OPTIONS - FIRESTOP SPRAY	SHEET 8
METAL PIPE/CONDUIT PENETRATIONS			
C-AJ-1353	2 & 3 HR	CONCRETE FLOOR OR CONCRETE/BLOCK WALL - SINGLE METAL PIPE/CONDUIT - SEALANT (2 HR) & BACKING (3 HR)	SHEET 8
C-AJ-1361	2 HR	CONCRETE FLOOR OR CONCRETE/BLOCK WALL - MULTIPLE METAL PIPE/CONDUITS, MAX 49 SQ. IN. OPENING	SHEET 8
C-AJ-1354	2 HR	CONCRETE FLOOR OR CONCRETE/BLOCK WALL - MULTIPLE METAL CONDUIT, MAX 6" DIA. OPENING	SHEET 9
F-A-1110	3 HR	MIN 2-1/2" CONCRETE FLOOR - 6" METAL PIPE/CONDUIT - CAST-IN DEVICE & DECK ADAPTER	SHEET 9
F-A-1093	2 HR F & T	EQUAL F & T RATINGS FOR EXPOSED METAL PIPE/CONDUIT PENETRATIONS	SHEET 9
F-A-1138	2 HR F & T	FLOOR SINK - SEALANT & DUCT WRAP	SHEET 9
F-A-1129	2 HR	CONCRETE FLOOR - TOILET DRAIN - CLOSET FLANGE GASKET	SHEET 9
W-L-1049	1 & 2 HR	GYPSUM WALL - SINGLE METAL PIPE/CONDUIT	SHEET 10
W-L-1168	1 & 2 HR	GYPSUM WALL - MULTIPLE METAL PIPE/CONDUIT IN RECTANGULAR OPENING	SHEET 10
INSULATED METAL PIPE PENETRATIONS			
C-AJ-5087	2 HR	CONCRETE FLOOR OR CONCRETE/BLOCK WALL - MAX 24" METAL PIPE WITH MAX 2" GLASS FIBER INSULATION	SHEET 10
C-AJ-5155	2 HR	CONCRETE FLOOR OR CONCRETE/BLOCK WALL - MAX 4" METAL PIPE WITH 1/2" - 3/4" AB/PVC (FOAM RUBBER) INSULATION	SHEET 10
F-A-5041	3 HR	CONCRETE FLOOR - MAX 4" METAL PIPE WITH MAX 1" GLASS FIBER INSULATION - CAST-IN DEVICE & DECK ADAPTER	SHEET 10
W-L-5014	1 & 2 HR	GYPSUM WALL - MAX 12" METAL PIPE WITH MAX 2" GLASS FIBER INSULATION	SHEET 11
W-L-5054	1 & 2 HR	GYPSUM WALL - MAX 4" METAL PIPE WITH 3/4-1" AB/PVC (FOAM RUBBER) INSULATION	SHEET 11
W-L-5262	1 & 2 HR	GYPSUM SHAFT WALL - MAX 2" METAL PIPE WITH 1" GLASS FIBER INSULATION	SHEET 11
PLASTIC PIPE/CONDUIT PENETRATIONS			
C-AJ-2578	3 HR	CONCRETE FLOOR OR CONCRETE/BLOCK WALL - MAX 2" PLASTIC PIPE - SEALANT & BACKING	SHEET 11
C-AJ-2282	2 HR	CONCRETE FLOOR OR CONCRETE/BLOCK WALL - MAX 4" PLASTIC PIPE - WRAP STRIP TUCK-IN	SHEET 11
C-AJ-2297	2 & 3 HR	CONCRETE FLOOR OR CONCRETE/BLOCK WALL - MAX 6" PLASTIC PIPE - FIRESTOP COLLAR	SHEET 11
F-A-2246	2 HR	MIN 2-1/2" CONCRETE FLOOR - MAX 4" PLASTIC PIPE - CAST-IN DEVICE	SHEET 12
F-A-2073	3 HR	MIN 2-1/2" CONCRETE FLOOR - MAX 4" PLASTIC PIPE - DROP IN COLLAR	SHEET 12
F-A-2077	2 HR	MIN 2-1/2" CONCRETE FLOOR - MAX 4" PLASTIC PIPE - WRAP STRIP TUCK-IN	SHEET 12
F-A-2185	2 HR	MIN 2-1/2" CONCRETE FLOOR - MAX 2" PLASTIC PIPE - SEALANT & BACKING	SHEET 12
F-A-2210	2 HR	MIN 2-1/2" CONCRETE FLOOR/METAL DECK - MAX 12" PLASTIC PIPE - FIRESTOP COLLAR	SHEET 12
F-A-2216	2 HR	MIN 2-1/2" CONCRETE FLOOR - TOILET DRAIN - CLOSET FLANGE GASKET	SHEET 13
W-L-2241	1 & 2 HR	GYPSUM WALL - MAX 2" PLASTIC PIPE - SEALANT ONLY	SHEET 13
W-L-2246	1 & 2 HR	GYPSUM WALL - MAX 3" PLASTIC PIPE - WRAP STRIP TUCK-IN	SHEET 13
W-L-2237	1 & 2 HR	GYPSUM WALL - MAX 4" PLASTIC PIPE - FIRESTOP COLLARS	SHEET 13
W-L-2257	2 HR	GYPSUM SHAFT WALL - MAX 4" PLASTIC PIPE - FIRESTOP COLLARS	SHEET 13
CABLE PENETRATIONS (NOT IN CONDUIT)			
C-AJ-3260	2 HR	CONCRETE FLOOR OR CONCRETE/BLOCK WALL - SINGLE EZ-PATH 44+	SHEET 13
C-AJ-3317	3 HR	CONCRETE FLOOR OR CONCRETE/BLOCK WALL - EZ-PATH 44+ GRID UP TO 16 UNITS GANGED	SHEET 13
F-A-3054	2, 3 & 4 HR	CONCRETE FLOOR - SINGLE EZ-PATH 44+	SHEET 13
W-J-3158	2 HR	CONCRETE/BLOCK WALL - EZ-PATH 44+ UP TO 5 UNITS GANGED	SHEET 14
W-L-3377	1, 2, 3 & 4 HR	GYPSUM WALL - SINGLE EZ-PATH SERIES 22, 33, 44, 44+	SHEET 14
W-L-3306	1 & 2 HR	GYPSUM WALL - EZ-PATH 44+ UP TO 5 UNITS GANGED	SHEET 14
W-L-3379	1 & 2 HR	GYPSUM WALL - ONE OR MORE CABLES UP TO 1/2" DIA. - CABLE GROMMET RFG2	SHEET 14
RETROFIT CABLE PENETRATIONS (FOR RENOVATIONS/ALTERATIONS)			
F-A-3063	2 HR	CONCRETE FLOOR - RETROFIT DEVICE	SHEET 14
F-A-3064	2 HR F & T	CONCRETE FLOOR - RETROFIT DEVICE - EQUAL F & T RATINGS FOR EXPOSED PENETRATIONS	SHEET 15
W-J-3240	2 HR	CONCRETE/BLOCK WALL - RETROFIT DEVICE	SHEET 15
W-L-3435	1 & 2 HR	GYPSUM WALL - RETROFIT DEVICE	SHEET 15
ELECTRICAL BUSWAY PENETRATIONS			
C-AJ-6008	3 HR	CONCRETE FLOOR OR CONCRETE/BLOCK WALL - SEALANT & BACKING	SHEET 15
C-BK-6001	3HR	CONCRETE FLOOR - 2 HR T RATING - PILLOWS & WRAP	SHEET 15
W-L-6001	1 & 2 HR	GYPSUM WALL - SEALANT & BACKING	SHEET 16
W-L-6005	1 & 2 HR	GYPSUM WALL - PILLOWS	SHEET 16
DUCT PENETRATIONS (WITHOUT DAMPERS)			
C-AJ-7027	2 HR	CONCRETE FLOOR OR CONCRETE/BLOCK WALL - MAX 60" X 36" DUCT - SEALANT & BACKING + RETAINING ANGLES	SHEET 16
C-AJ-7143	2 HR	CONCRETE FLOOR OR CONCRETE/BLOCK WALL - MAX 60" X 36" DUCT - INSULATED - SEALANT & BACKING + RETAINING ANGLES	SHEET 16
C-AJ-7023	2 & 3 HR	CONCRETE FLOOR OR CONCRETE/BLOCK WALL - MAX 24" DIA. ROUND DUCT - SEALANT & BACKING	SHEET 16
W-J-7092	2 HR	CONCRETE/BLOCK WALL - MAX 92" X 96" DUCT - OPTIONAL INSULATION - FYREFLANGE GASKET	SHEET 16
W-L-7025	1 & 2 HR	GYPSUM WALL - MAX 100" X 100" DUCT - SEALANT & RETAINING ANGLES	SHEET 17
W-L-7026	1 & 2 HR	GYPSUM WALL - MAX 24" DIA. ROUND DUCT - SEALANT ONLY	SHEET 17
W-L-7029	1 & 2 HR	GYPSUM WALL - MAX 24" X 24" DUCT - SEALANT ONLY	SHEET 17
W-L-7145	1 & 2 HR	GYPSUM WALL - INSULATED RECTANGULAR DUCT - SEALANT & BACKING	SHEET 17
W-L-7175	1 & 2 HR	GYPSUM WALL - INSULATED ROUND DUCT - SEALANT ONLY	SHEET 17
W-L-7099	1 & 2 HR	GYPSUM WALL - INSULATED GREASE DUCT - SEALANT & BACKING	SHEET 17
W-L-7096	1 & 2 HR	GYPSUM SHAFT WALL - MAX 6" DIA. ROUND DUCT THRU SLEEVE - SEALANT & BACKING	SHEET 18
W-L-7090	1 & 2 HR	GYPSUM SHAFT WALL - MAX 8" X 8" DUCT, NO SLEEVE - SEALANT & BACKING	SHEET 18
W-L-7252	1 & 2 HR	GYPSUM SHAFT WALL - MAX 12" X 12" DUCT THRU SLEEVE - SEALANT & BACKING	SHEET 18
W-L-7238	1 & 2 HR	GYPSUM SHAFT WALL - MAX 24" X 40" DUCT, NO SLEEVE - FYREFLANGE GASKET	SHEET 18
W-L-7253	1 & 2 HR	GYPSUM SHAFT WALL - STEEL STRUT, CHANNEL, CABLE OR THREADED ROD	SHEET 18
LARGE OPENINGS & MIXED PENETRANTS			
C-AJ-8113	2 HR	CONCRETE FLOOR OR CONCRETE/BLOCK WALL - SEALANT & BACKING	SHEET 19
C-AJ-8093	2 & 3 HR	CONCRETE FLOOR OR CONCRETE/BLOCK WALL - PILLOWS	SHEET 19
W-L-8026	1 & 2 HR	GYPSUM WALL - SEALANT & BACKING	SHEET 20
W-L-8050	1 & 2 HR	GYPSUM WALL - PILLOWS	SHEET 20
ELECTRICAL & UTILITY BOXES			
C-AJ-1217	2 HR	CONCRETE FLOOR OR CONCRETE/BLOCK WALL - PULL OR JUNCTION BOX - SEALANT	SHEET 20
CLIV R14288	1 & 2 HR	GYPSUM WALL - ELEC. BOX - PUTTY PADS OR ELEC. BOX INSERTS	SHEET 21
W-L-1446	1 & 2 HR	GYPSUM WALL - PULL OR JUNCTION BOX - SEALANT	SHEET 21
W-L-7307	1 & 2 HR	GYPSUM WALL - ELEC. UTILITY OR MED GAS VALVE BOX - E-WRAP	SHEET 21
CIRCUIT INTEGRITY			
STIAF 120-01	1 & 2 HR	MIN 1" STEEL CONDUIT - E-WRAP	SHEET 21
FUEL LINE PROTECTION			
FP-3	2 HR	1" - 4" STEEL PIPE - E-WRAP	SHEET 22
FP-4	2 HR	3" - 4" OUTER CONTAINMENT PIPE - E-WRAP	SHEET 22
C-AJ-5437	2 HR F & T	PIPE PENETRATION - MAX 4" METAL PIPE WITH E-WRAP THRU CONCRETE/BLOCK FLOOR OR WALL - PUTTY OR SEALANT	SHEET 22

UL FIRE RESISTANCE DIRECTORY NOMENCLATURE			
Through Penetrations			
First letter represents what is being penetrated:	Second letter(s) provide more information about the floor or wall:	Four digit number describes the penetrating item(s):	Example: C-AJ-1150
F = Floor W = Wall C = Floors or Walls (combined)	A = Concrete Floors with a min thickness that is Less than or Equal to 5" B = Concrete Floors with a min thickness that is Greater than 5" C = Framed Floors E = For-Ceiling Assemblies consisting of Concrete with Membrane Protection. J = Concrete or Masonry Walls with a min thickness that is Less than or Equal to 8" L = Framed Walls	0000-0999 = Blank Openings 1000-1999 = Metal Pipe, Conduit, or Tubing 2000-2999 = Non-Metallic Pipe, Conduit, or Tubing 3000-3999 = Cables 4000-4999 = Cable Trays 5000-5999 = Insulated Pipes 6000-6999 = Miscellaneous Electrical (Busway) 7000-7999 = Miscellaneous Mechanical 8000-8999 = Mixed Penetrating Items 9000-9999 = Reserved for Future Use	C = Floor or Wall Penetration A = Concrete Floor that is 5" or less J = Concrete or Masonry Walls that are 8" or less 1150 = Metal Pipe, Conduit, or Tubing
Joint Systems			
First letter identifies the type joint:	Second letter(s) provide more information about the floor or wall:	Four digit number describes the joint width:	Example: HW-D-0757
CJ = Floor FF = Wall WW = Floors or Walls (combined) FW = Floor to Wall HW = Head to Wall BW = Bottom of Wall	S = No Movement (Static) D = Allows Movement (Dynamic)	0000-0999 = Less than or Equal to 2" 1000-1999 = Greater than 2" and Less than or Equal to 6" 2000-2999 = Greater than 6" and Less than or Equal to 12" 3000-3999 = Greater than 12" and Less than or Equal to 24" 4000-4999 = Greater than 24"	HW = Head to Wall D = Allows Movement (Dynamic) 0757 = Less than or Equal to 2"

GENERAL NOTES:

- Refer to section 07 84 00 of the specifications. For Quality Control requirements, refer to the Quality Control portion of the specification.
- Details shown are typical details. If field conditions do not match requirements of typical details, approved alternate details shall be utilized. Field conditions and dimensions need to be verified for compliance with the details, including but not limited to the following:
 - Type and thickness of fire-rated construction. The minimum assembly rating of the firestop assembly shall meet or exceed the highest rating of the adjacent construction.
- If alternate details matching the field conditions are not available, manufacturer's engineering judgment drawings are acceptable. Engineering Judgments shall follow the International Firestop Council (IFC) Guidelines for Evaluating Firestop Systems Engineering Judgments.
- References:
 - UL Fire Resistance Directory; Current Edition or UL Product iQ™
 - NFPA 101 Life Safety Code
 - All governing local and regional building codes
 - Intertek Directory of Building Products
- Firestop System installation must meet requirements of ASTM E-814 (UL 1479), ASTM E1966 (UL 1479), ASTM 1966 (UL 2079), ASTM E2307, or ULC-S115 (as required) in tested assemblies that provide a fire rating equal to that of the surrounding construction.

PROJECT NAME:

PROJECT_NAME:

PROJECT LOCATION:

PROJECT_LOCATION:

ARCHITECT/CONSULTANT:

ARCHITECT/CONSULTANT:


TITLE: TYPICAL FIRESTOP DETAILS - HEALTHCARE FACILITY

Specified Technologies Inc.
210 Evans Way Somerville, NJ 08876

Toll Free: (800)992-1180
Phone: (908)526-8000
FAX (908)231-8415
E-Mail: techserv@stifirestop.com
Website: www.stifirestop.com



Table with columns for ANSUL2079 and CANULC S115, detailing assembly ratings, nominal joint width, and movement capabilities.




- 1. Floor Assembly - The fire-rated fluted steel deck/concrete floor assembly shall be constructed of the materials and in the manner described in the individual D700, D800, or D900 Series Floor-Ceiling Design in the UL Fire Resistance Directory and shall include the following construction features:
A. Steel Floor And Floor Units - Max 3 in. (76 mm) deep galv steel fluted floor units.
B. Concrete - Min 2-1/2 in. (64 mm) thick reinforced concrete, as measured from the top plane of the floor units.
C. Structural Steel Support - Steel beam, as specified in the individual D700, D800, or D900 Series Floor-Ceiling Design, used to support steel floor units. Steel beam centered over and parallel with wall assembly.

Specified Technologies Inc. 210 Evans Way Somerville, NJ 08876. Includes UL logo and contact information.

Continuation of technical specifications for fire-rated floor assembly, including details on steel attachment clips, roof insulation, and roof deck.

Specified Technologies Inc. 210 Evans Way Somerville, NJ 08876. Includes UL logo and contact information.

Table with columns for ANSUL2079 and CANULC S115, detailing assembly ratings, nominal joint width, and movement capabilities.




- D. Spray-Applied Fire Resistive Material - After installation of the steel attachment clips (Item 2B), steel floor units and structural steel support to be sprayed with the min thickness of material specified in the individual D700, D800, or D900 Series Design. The flutes of the steel floor units are to be filled with material across the entire top flange of the steel beam. Additional material shall be applied to the web of the steel beam on each side of the wall. For a 1 hr fire rated assembly, the thickness of material applied to each side of the steel beam web shall be 1/8 in. (21 mm). For a 2 hr fire rated assembly, the thickness of material applied to each side of the steel beam web shall be 1-3/8 in. (35 mm).
E. Light Gauge Framing - Slotted Ceiling Runner - Slotted ceiling runner may be used as an alternate to the ceiling runner in Item 2A. Slotted ceiling runner to consist of galv steel channel with slotted flanges sized to accommodate steel studs (Item 2C). Ceiling runner is secured to steel beam (Item 1A) with steel attachment clips (Item 2B) spaced max 24 in. (610 mm) OC. Ceiling runner or deflection channel to be centered beneath and parallel with bottom flange of steel beam. A clearance equal to the required thickness of spray-applied fireproofing material (Item 1D) shall be maintained between the top of the ceiling runner or deflection channel and the bottom flange of the steel beam.

Specified Technologies Inc. 210 Evans Way Somerville, NJ 08876. Includes UL logo and contact information.

Continuation of technical specifications for fire-rated wall assembly, including details on wall assembly, steel floor and ceiling runners, and light gauge framing.

Specified Technologies Inc. 210 Evans Way Somerville, NJ 08876. Includes UL logo and contact information.

Table with columns for ANSUL2079 and CANULC S115, detailing assembly ratings, nominal joint width, and movement capabilities.




- D. Gypsum Board - Gypsum board sheets installed to a min total 5/8 in. (16 mm) or 1-1/4 in. (32 mm) thickness on each side of wall for 1 and 2 hr fire rated assemblies, respectively. Wall to be constructed in accordance with the individual U400 or V400 Series Design in the UL Fire Resistance Directory, except that a max 1 in. (25 mm) high gap shall be maintained between the top of the gypsum board and the bottom plane of the spray applied fire resistive material on the structural steel support member. The screws attaching the gypsum board to the studs along the top of the wall shall be located 1 in. (25 mm) below the bottom of the ceiling runner. No gypsum board attachment screws shall be driven into the ceiling runner or into the optional deflection channel.
The hourly fire rating of the joint system is equal to the hourly fire rating of the wall.
3. Joint System - Max separation between spray applied fire resistive material on bottom of structural support member and top of gypsum board (at time of installation of joint system) is 3/4 or 1-1/2 in. (19 or 38 mm). The joint system is designed to accommodate a max 50 or 100 percent compression or extension from its installed width as measured between bottom plane of the protective material on the steel beam and the top of the gypsum board. When Item 3B1 is used in lieu of the strips of mineral wool described in Item 3B, the maximum joint width is 3/4 in. (19 mm) and the movement capabilities are 100% compression or extension. The joint system shall consist of forming and fill materials, with or without a deflection channel (Item 3A), as follows:
A. Deflection Channel - (Optional, Not Shown) - Max 2 in. (51 mm) deep min 24 gauge galv steel channel sized to accommodate ceiling runner (Item 2A). Deflection channel installed parallel with and centered beneath bottom flange of steel beam (Item 1C) and secured to steel beam with steel clips (Item 2B) spaced max 16 in. (406 mm) OC. The ceiling runner (Item 2A) is installed within the deflection channel to maintain a 1/2 in. (13 mm) to 3/4 in. (19 mm) gap between the top of the ceiling runner and the top of the deflection channel. A clearance equal to the required thickness of spray-applied fireproofing material (Item 1D) shall be maintained between the top of the ceiling runner or deflection channel and the bottom flange of the steel beam. The ceiling runner nests inside the deflection channel without attachment.

Specified Technologies Inc. 210 Evans Way Somerville, NJ 08876. Includes UL logo and contact information.

Continuation of technical specifications for fire-rated wall assembly, including details on gypsum board, joint system, and forming material.

Specified Technologies Inc. 210 Evans Way Somerville, NJ 08876. Includes UL logo and contact information.

Table with columns for ANSUL2079 and CANULC S115, detailing assembly ratings, nominal joint width, and movement capabilities.



- 1. Floor Assembly - The fire-rated fluted steel deck/concrete floor assembly shall be constructed of the materials and in the manner described in the individual D700 or D900 Series Floor-Ceiling Design in the UL Fire Resistance Directory and shall include the following construction features:
A. Steel Floor And Floor Units - Max 3 in. (76 mm) deep galv steel fluted floor units.
B. Concrete - Min 2-1/2 in. (64 mm) thick reinforced lightweight or normal weight (100-150 pcf or 1600-2400 kg/m3) concrete, as measured from the top plane of the floor units.
C. Structural Steel Support - Steel beam, as specified in the individual D700 or D900 Series Floor-Ceiling Design, used to support steel floor units. Steel beam parallel with wall assembly and 8 in. (203 mm) max from wall assembly.

Specified Technologies Inc. 210 Evans Way Somerville, NJ 08876. Includes UL logo and contact information.

Continuation of technical specifications for fire-rated wall assembly, including details on forming material, fill void or cavity material, and steel floor and ceiling runners.

Specified Technologies Inc. 210 Evans Way Somerville, NJ 08876. Includes UL logo and contact information.

- GENERAL NOTES:
1. Refer to section 07 84 00 of the specifications. For Quality Control requirements, refer to the Quality Control portion of the specification.
2. Details shown are typical details. If field conditions do not match requirements of typical details, approved alternate details shall be utilized. Field conditions and dimensions need to be verified for compliance with the details, including but not limited to the following:
- Type and thickness of fire-rated construction. The minimum assembly rating of the firestop assembly shall meet or exceed the highest rating of the adjacent construction.
3. If alternate details matching the field conditions are not available, manufacturer's engineering judgment drawings are acceptable. Engineering Judgments shall follow the International Firestop Council (IFC) Guidelines for Evaluating Firestop Systems Engineering Judgments.
4. References:
- UL Fire Resistance Directory; Current Edition
- NFPA 101 Life Safety Code
- All governing local and regional building codes
5. Firestop System installation must meet requirements of ASTM E-814 (UL 1479), ASTM E1966 (UL 1479), ASTM 1966 (UL 2079), ASTM E2307, or ULC-S115 (as required) in tested assemblies that provide a fire rating equal to that of the surrounding construction.

DIVISION 4: Masonry Protection
DIVISION 7: Thermal & Moisture Protection
DIVISION 9: Finishes
DIVISION 22: Plumbing
DIVISION 23: HVAC
DIVISION 26: Electrical
DIVISION 27: Communications
PROJECT NAME: PROJECT_NAME
PROJECT LOCATION: PROJECT_LOCATION
ARCHITECT/CONSULTANT: ARCHITECT/CONSULTANT
TITLE: STI FIRESTOP SYSTEMS
Specified Technologies Inc.
210 Evans Way Somerville, NJ 08876
Toll Free: (800)992-1180
Phone: (908)526-8000
FAX (908)231-8415
E-Mail:techserv@stifirestop.com
Website:www.stifirestop.com

INDEX

Classified by Underwriters Laboratories, Inc. to ANSIUL 2079 and CANULC S115

System No. HW-D-0548

ANSIUL 2079	CANULC S115
Assembly Ratings - 1 and 2 Hr (See Item 2)	F Ratings - 1 and 2 Hr (See Item 2)
Maximum Joint Width - 3/4, 1 or 1-1/2 in. (See Item 3)	FT Ratings - 1 and 2 Hr (See Item 2)
Class II Movement Capabilities - 25, 50% or 100% Compression or Extension (See Item 3)	FTH Ratings - 1 and 2 Hr (See Item 2)
L Rating At Ambient - Less Than 1 CFMq/ft	Maximum Joint Width - 19, 25 or 38 mm (See Item 3)
L Rating At 400 F - Less Than 1 CFMq/ft	Class II Movement Capabilities - 50 or 100 % Compression or Extension (See Item 3)
	L Rating At Ambient - Less Than 1 CFMq/ft
	L Rating At 400 F - Less Than 1 CFMq/ft

Specified Technologies Inc. 210 Evans Way Somerville, NJ 08876
 Reproduced courtesy of Underwriters Laboratories, Inc. Created or Revised: March 18, 2020
 (800)992-1180 • (908)226-8000 • FAX (908)231-8415 • E-Mail:techserv@stifirestop.com • Website:www.stifirestop.com

UL US FW-D-0548 PAGE 1 OF 2

Classified by Underwriters Laboratories, Inc. to ANSIUL 2079 and CANULC S115

System No. HW-D-0644

ANSIUL 2079	CANULC S115
Assembly Ratings - 1 and 2 Hr (See Items 1 and 4C)	F Ratings - 1 and 2 Hr (See Items 1 and 4C)
Nominal Joint Width - 3/4 or 1-1/2 in. (See Items 1 and 4C)	FT Ratings - 1 and 2 Hr (See Items 1 and 4C)
Class II Movement Capabilities - 25, 50% or 100% Compression or Extension (See Item 5)	FTH Ratings - 1 and 2 Hr (See Items 1 and 4C)
L Rating At Ambient - Less Than 1 CFMq/ft	Nominal Joint Width - 19 mm to 38 mm (See Item 5)
L Rating At 400 F - Less Than 1 CFMq/ft	Class II Movement Capabilities - 25, 50% or 100% Compression or Extension (See Item 5)
	L Rating At Ambient - Less Than 1.55 L/m/ft
	L Rating At 400 F - Less Than 1.55 L/m/ft

Specified Technologies Inc. 210 Evans Way Somerville, NJ 08876
 Reproduced courtesy of Underwriters Laboratories, Inc. Created or Revised: November 17, 2017
 (800)992-1180 • (908)226-8000 • FAX (908)231-8415 • E-Mail:techserv@stifirestop.com • Website:www.stifirestop.com

UL US FW-D-0644 PAGE 1 OF 2

Classified by Underwriters Laboratories, Inc. to ANSIUL 2079 and CANULC S115

System No. HW-D-0644

ANSIUL 2079	CANULC S115
Assembly Ratings - 1 and 2 Hr (See Items 1 and 4C)	F Ratings - 1 and 2 Hr (See Items 1 and 4C)
Nominal Joint Width - 3/4 or 1-1/2 in. (See Items 1 and 4C)	FT Ratings - 1 and 2 Hr (See Items 1 and 4C)
Class II Movement Capabilities - 25, 50% or 100% Compression or Extension (See Item 5)	FTH Ratings - 1 and 2 Hr (See Items 1 and 4C)
L Rating At Ambient - Less Than 1 CFMq/ft	Nominal Joint Width - 19 mm to 38 mm (See Item 5)
L Rating At 400 F - Less Than 1 CFMq/ft	Class II Movement Capabilities - 25, 50% or 100% Compression or Extension (See Item 5)
	L Rating At Ambient - Less Than 1.55 L/m/ft
	L Rating At 400 F - Less Than 1.55 L/m/ft

Specified Technologies Inc. 210 Evans Way Somerville, NJ 08876
 Reproduced courtesy of Underwriters Laboratories, Inc. Created or Revised: November 17, 2017
 (800)992-1180 • (908)226-8000 • FAX (908)231-8415 • E-Mail:techserv@stifirestop.com • Website:www.stifirestop.com

UL US FW-D-0644 PAGE 2 OF 2

Classified by Underwriters Laboratories, Inc. to ANSIUL 2079 and CANULC S115

System No. HW-D-0548

ANSIUL 2079	CANULC S115
Assembly Ratings - 1 and 2 Hr (See Item 2)	F Ratings - 1 and 2 Hr (See Item 2)
Maximum Joint Width - 3/4, 1 or 1-1/2 in. (See Item 3)	FT Ratings - 1 and 2 Hr (See Item 2)
Class II Movement Capabilities - 25, 50% or 100% Compression or Extension (See Item 3)	FTH Ratings - 1 and 2 Hr (See Item 2)
L Rating At Ambient - Less Than 1 CFMq/ft	Maximum Joint Width - 19, 25 or 38 mm (See Item 3)
L Rating At 400 F - Less Than 1 CFMq/ft	Class II Movement Capabilities - 50 or 100 % Compression or Extension (See Item 3)
	L Rating At Ambient - Less Than 1 CFMq/ft
	L Rating At 400 F - Less Than 1 CFMq/ft

Specified Technologies Inc. 210 Evans Way Somerville, NJ 08876
 Reproduced courtesy of Underwriters Laboratories, Inc. Created or Revised: March 18, 2020
 (800)992-1180 • (908)226-8000 • FAX (908)231-8415 • E-Mail:techserv@stifirestop.com • Website:www.stifirestop.com

UL US FW-D-0548 PAGE 1 OF 2

Classified by Underwriters Laboratories, Inc. to ANSIUL 2079 and CANULC S115

System No. HW-D-0644

ANSIUL 2079	CANULC S115
Assembly Ratings - 1 and 2 Hr (See Items 1 and 4C)	F Ratings - 1 and 2 Hr (See Items 1 and 4C)
Nominal Joint Width - 3/4 or 1-1/2 in. (See Items 1 and 4C)	FT Ratings - 1 and 2 Hr (See Items 1 and 4C)
Class II Movement Capabilities - 25, 50% or 100% Compression or Extension (See Item 5)	FTH Ratings - 1 and 2 Hr (See Items 1 and 4C)
L Rating At Ambient - Less Than 1 CFMq/ft	Nominal Joint Width - 19 mm to 38 mm (See Item 5)
L Rating At 400 F - Less Than 1 CFMq/ft	Class II Movement Capabilities - 25, 50% or 100% Compression or Extension (See Item 5)
	L Rating At Ambient - Less Than 1.55 L/m/ft
	L Rating At 400 F - Less Than 1.55 L/m/ft

Specified Technologies Inc. 210 Evans Way Somerville, NJ 08876
 Reproduced courtesy of Underwriters Laboratories, Inc. Created or Revised: November 17, 2017
 (800)992-1180 • (908)226-8000 • FAX (908)231-8415 • E-Mail:techserv@stifirestop.com • Website:www.stifirestop.com

UL US FW-D-0644 PAGE 2 OF 2

Classified by Underwriters Laboratories, Inc. to ANSIUL 2079 and CANULC S115

System No. HW-D-0644

ANSIUL 2079	CANULC S115
Assembly Ratings - 1 and 2 Hr (See Items 1 and 4C)	F Ratings - 1 and 2 Hr (See Items 1 and 4C)
Nominal Joint Width - 3/4 or 1-1/2 in. (See Items 1 and 4C)	FT Ratings - 1 and 2 Hr (See Items 1 and 4C)
Class II Movement Capabilities - 25, 50% or 100% Compression or Extension (See Item 5)	FTH Ratings - 1 and 2 Hr (See Items 1 and 4C)
L Rating At Ambient - Less Than 1 CFMq/ft	Nominal Joint Width - 19 mm to 38 mm (See Item 5)
L Rating At 400 F - Less Than 1 CFMq/ft	Class II Movement Capabilities - 25, 50% or 100% Compression or Extension (See Item 5)
	L Rating At Ambient - Less Than 1.55 L/m/ft
	L Rating At 400 F - Less Than 1.55 L/m/ft

Specified Technologies Inc. 210 Evans Way Somerville, NJ 08876
 Reproduced courtesy of Underwriters Laboratories, Inc. Created or Revised: November 17, 2017
 (800)992-1180 • (908)226-8000 • FAX (908)231-8415 • E-Mail:techserv@stifirestop.com • Website:www.stifirestop.com

UL US FW-D-0644 PAGE 2 OF 2

Classified by Underwriters Laboratories, Inc. to ANSIUL 2079 and CANULC S115

System No. HW-D-0548

ANSIUL 2079	CANULC S115
Assembly Ratings - 1 and 2 Hr (See Item 2)	F Ratings - 1 and 2 Hr (See Item 2)
Maximum Joint Width - 3/4, 1 or 1-1/2 in. (See Item 3)	FT Ratings - 1 and 2 Hr (See Item 2)
Class II Movement Capabilities - 25, 50% or 100% Compression or Extension (See Item 3)	FTH Ratings - 1 and 2 Hr (See Item 2)
L Rating At Ambient - Less Than 1 CFMq/ft	Maximum Joint Width - 19, 25 or 38 mm (See Item 3)
L Rating At 400 F - Less Than 1 CFMq/ft	Class II Movement Capabilities - 50 or 100 % Compression or Extension (See Item 3)
	L Rating At Ambient - Less Than 1 CFMq/ft
	L Rating At 400 F - Less Than 1 CFMq/ft

Specified Technologies Inc. 210 Evans Way Somerville, NJ 08876
 Reproduced courtesy of Underwriters Laboratories, Inc. Created or Revised: March 18, 2020
 (800)992-1180 • (908)226-8000 • FAX (908)231-8415 • E-Mail:techserv@stifirestop.com • Website:www.stifirestop.com

UL US FW-D-0548 PAGE 1 OF 2

Classified by Underwriters Laboratories, Inc. to ANSIUL 2079 and CANULC S115

System No. HW-D-0644

ANSIUL 2079	CANULC S115
Assembly Ratings - 1 and 2 Hr (See Items 1 and 4C)	F Ratings - 1 and 2 Hr (See Items 1 and 4C)
Nominal Joint Width - 3/4 or 1-1/2 in. (See Items 1 and 4C)	FT Ratings - 1 and 2 Hr (See Items 1 and 4C)
Class II Movement Capabilities - 25, 50% or 100% Compression or Extension (See Item 5)	FTH Ratings - 1 and 2 Hr (See Items 1 and 4C)
L Rating At Ambient - Less Than 1 CFMq/ft	Nominal Joint Width - 19 mm to 38 mm (See Item 5)
L Rating At 400 F - Less Than 1 CFMq/ft	Class II Movement Capabilities - 25, 50% or 100% Compression or Extension (See Item 5)
	L Rating At Ambient - Less Than 1.55 L/m/ft
	L Rating At 400 F - Less Than 1.55 L/m/ft

Specified Technologies Inc. 210 Evans Way Somerville, NJ 08876
 Reproduced courtesy of Underwriters Laboratories, Inc. Created or Revised: November 17, 2017
 (800)992-1180 • (908)226-8000 • FAX (908)231-8415 • E-Mail:techserv@stifirestop.com • Website:www.stifirestop.com

UL US FW-D-0644 PAGE 2 OF 2

GENERAL NOTES:

1. Refer to section 07 84 00 of the specifications. For Quality Control requirements, refer to the Quality Control portion of the specification.
2. Details shown are typical details. If field conditions do not match requirements of typical details, approved alternate details shall be utilized. Field conditions and dimensions need to be verified for compliance with the details, including but not limited to the following:
 - Type and thickness of fire-rated construction. The minimum assembly rating of the firestop assembly shall meet or exceed the highest rating of the adjacent construction.
3. If alternate details matching the field conditions are not available, manufacturer's engineering judgment drawings are acceptable. Engineering Judgments shall follow the International Firestop Council (IFC) Guidelines for Evaluating Firestop Systems Engineering Judgments.

4. References:
 - UL Fire Resistance Directory; Current Edition
 - NFPA 101 Life Safety Code
 - All governing local and regional building codes
5. Firestop System installation must meet requirements of ASTM E-814 (UL 1479), ASTM E1966 (UL 1479), ASTM 1966 (UL 2079), ASTM E2307, or ULC-S115 (as required) in tested assemblies that provide a fire rating equal to that of the surrounding construction.

DIVISION 4: Masonry
 DIVISION 7: Thermal & Moisture Protection
 DIVISION 9: Finishes
 DIVISION 22: Plumbing
 DIVISION 23: HVAC
 DIVISION 26: Electrical
 DIVISION 27: Communications

PROJECT NAME:

PROJECT_NAME:

PROJECT LOCATION:

PROJECT_LOCATION:

ARCHITECT/CONSULTANT:

ARCHITECT/CONSULTANT:

TITLE:


STI FIRESTOP SYSTEMS

Specified Technologies Inc.
 210 Evans Way Somerville, NJ 08876


Toll Free: (800)992-1180
 Phone: (908)526-8000
 FAX (908)231-8415
 E-Mail:techserv@stifirestop.com
 Website:www.stifirestop.com



Table with columns for ANSUL2079 and CANULC S115, listing assembly ratings, nominal joint width, and movement capabilities for System No. HW-D-0642.



Specified Technologies Inc. 210 Evans Way Somerville, NJ 08876. Reproduced courtesy of Underwriters Laboratories, Inc.



- 1. Floor Assembly - The fire-rated full steel deck/concrete floor assembly shall be constructed of the materials and in the manner described in the individual D700, D900, or D900 Series Floor-Ceiling Design in the UL Fire Resistance Directory...


Specified Technologies Inc. 210 Evans Way Somerville, NJ 08876. Reproduced courtesy of Underwriters Laboratories, Inc.

- 2. Shaft Wall Assembly - The 1 hr or 2 hr fire rated shaft wall assembly shall be constructed of the materials and in the manner described in the individual U400, V400 or V400 Series Wall and Partition Design in the UL Fire Resistance Directory...


- 3. Joint System - Max separation between spray applied fire resistive material on bottom of structural support member and top of gypsum board is 1 1/2 in. (38 mm)...

Specified Technologies Inc. 210 Evans Way Somerville, NJ 08876. Reproduced courtesy of Underwriters Laboratories, Inc.

Table with columns for ANSUL2079 and CANULC S115, listing assembly ratings, maximum joint width, and movement capabilities for System No. HW-D-0645.



Specified Technologies Inc. 210 Evans Way Somerville, NJ 08876. Reproduced courtesy of Underwriters Laboratories, Inc.



- 1. Floor Assembly - The fire-rated full steel deck/concrete floor assembly shall be constructed of the materials and in the manner described in the individual D700 or D900 Series Floor-Ceiling Design in the UL Fire Resistance Directory...

Specified Technologies Inc. 210 Evans Way Somerville, NJ 08876. Reproduced courtesy of Underwriters Laboratories, Inc.

- F. Spray Applied Fire Resistive Material - After installation of steel attachment clip and steel lath (Items 1D and 1E), the steel floor and structural steel support to be sprayed with the min thickness of material specified in the individual D700 or D900 Series Design.

- 1A. Roof Assembly - (Not Shown) - An alternate to the floor assembly, a fire-rated full steel deck roof assembly may be used. The roof assembly shall be constructed of the materials and in the manner described in the individual P700 or P700 Series Roof-Ceiling Design in the UL Fire Resistance Directory.

Specified Technologies Inc. 210 Evans Way Somerville, NJ 08876. Reproduced courtesy of Underwriters Laboratories, Inc.

- A. Forming Material - Sections of nominal 4 pcf (64 kg/m3) mineral wool batt insulation to be compressed 50 percent in thickness and installed on edge first to completely fill the gap above the top of the gypsum board (Item 2D) and the gap below the top of the gypsum board (Item 2E).

- 4. Joint System - Max separation between bottom plane of spray-applied fire resistive material on the steel attachment clip (Item 1D) and the top of the gypsum board is 3/4 in. (19 mm) or 1 in. (25 mm)...

Specified Technologies Inc. 210 Evans Way Somerville, NJ 08876. Reproduced courtesy of Underwriters Laboratories, Inc.

- 2. Shaft Wall Assembly - The 1 hr or 2 hr fire rated shaft wall assembly shall be constructed of the materials and in the manner described in the individual U400, V400 or V400 Series Wall and Partition Design in the UL Fire Resistance Directory.

- 3. Joint System - Max separation between bottom plane of spray-applied fire resistive material on the steel attachment clip (Item 1D) and the top of the gypsum board is 1 1/2 in. (38 mm)...

Specified Technologies Inc. 210 Evans Way Somerville, NJ 08876. Reproduced courtesy of Underwriters Laboratories, Inc.

- A. Forming Material - Non-4 pcf (64 kg/m3) density mineral wool batt insulation. Sections of mineral wool batt to be 1 in. (25 mm) thick, compressed a min of 50 percent in thickness and inserted cut-edge first into the gap above the gypsum liner panel (Item 2C).

- 4. Joint System - Max separation between bottom plane of spray-applied fire resistive material on the steel attachment clip (Item 1D) and the top of the gypsum board is 3/4 in. (19 mm) or 1 in. (25 mm)...

Specified Technologies Inc. 210 Evans Way Somerville, NJ 08876. Reproduced courtesy of Underwriters Laboratories, Inc.

- 1. Floor Assembly - The fire-rated full steel deck/concrete floor assembly shall be constructed of the materials and in the manner described in the individual D700 or D900 Series Floor-Ceiling Design in the UL Fire Resistance Directory...

- 1. Floor Assembly - Min 1/2 in. (14 mm) thick steel reinforced lightweight or normal weight (100-150 pcf or 1600-2400 kg/m3) concrete, as measured on the top plane of the floor units.

Specified Technologies Inc. 210 Evans Way Somerville, NJ 08876. Reproduced courtesy of Underwriters Laboratories, Inc.

- B. Steel Studs - "C"-shaped steel studs to be min 2 1/2 in. (64 mm) wide and formed of min 24 MSG galv steel. Studs out 1/2 to 3/4 in. (13 to 19 mm) less in length than assembly height with bottom resting in and resting on floor runner and with top resting in slotted ceiling track.

- 1. Floor Assembly - Min 1/2 in. (14 mm) thick steel reinforced lightweight or normal weight (100-150 pcf or 1600-2400 kg/m3) concrete, as measured on the top plane of the floor units.

Specified Technologies Inc. 210 Evans Way Somerville, NJ 08876. Reproduced courtesy of Underwriters Laboratories, Inc.

- 2. Shaft Wall Assembly - The 1 hr or 2 hr fire rated shaft wall assembly shall be constructed of the materials and in the manner described in the individual U400, V400 or V400 Series Wall and Partition Design in the UL Fire Resistance Directory.

- 3. Joint System - Max separation between bottom plane of spray-applied fire resistive material on the steel attachment clip (Item 1D) and the top of the gypsum board is 1 1/2 in. (38 mm)...

Specified Technologies Inc. 210 Evans Way Somerville, NJ 08876. Reproduced courtesy of Underwriters Laboratories, Inc.

GENERAL NOTES:


- 1. Refer to section 07 84 00 of the specifications. For Quality Control requirements, refer to the Quality Control portion of the specification.
2. Details shown are typical details. If field conditions do not match requirements of typical details, approved alternate details shall be utilized.

- 4. References:
- UL Fire Resistance Directory; Current Edition
- NFPA 101 Life Safety Code
- All governing local and regional building codes
5. Firestop System installation must meet requirements of ASTM E-814 (UL 1479), ASTM E1966 (UL 1479), ASTM 1966 (UL 2079), ASTM E2307, or ULC-S115 (as required) in tested assemblies that provide a fire rating equal to that of the surrounding construction.

DIVISION 4: Masonry
DIVISION 7: Thermal & Moisture Protection
DIVISION 9: Finishes
DIVISION 22: Plumbing
DIVISION 23: HVAC
DIVISION 26: Electrical
DIVISION 27: Communications

PROJECT NAME:
PROJECT LOCATION:
ARCHITECT/CONSULTANT:
ARCHITECT/CONSULTANT:

TITLE:
STI FIRESTOP SYSTEMS
Specified Technologies Inc.
210 Evans Way Somerville, NJ 08876
Toll Free: (800)992-1180
Phone: (908)526-8000
FAX (908)231-8415
E-Mail:techserv@stifirestop.com
Website:www.stifirestop.com



INDEX

Classified by Underwriters Laboratories, Inc. to ANSIUL 2079. System No. HW-D-0140. Assembly Rating - 3 Hr. Normal Joint Width - 1 in. I Rating At Ambient - Less Than 1 CFMLin Ft. L Rating At 400°F - Less Than 1 CFMLin Ft. Class II Movement Capabilities - 15% Compression or Extension. Includes diagrams for floor assembly and wall assembly.

Classified by Underwriters Laboratories, Inc. to ANSIUL 2079 and CANULC S115. System No. HW-D-0086. Assembly Ratings - 1, 2, 3 and 4 Hr. Normal Joint Widths - 1, 1-1/2 and 2 in. L Rating At Ambient - Less Than 1 CFMLin Ft. L Rating At 400°F - Less Than 1 CFMLin Ft. Class II Movement Capabilities - 30, 40 or 50% Compression and Extension. Includes diagrams and a table of ratings for ANSUL 2079 and CANULC S115.

Classified by Underwriters Laboratories, Inc. to ANSIUL 2079 and CANULC S115. System No. BW-S-0003. Assembly Ratings - 1 and 2 Hr (See Item 2). I Rating At Ambient - Less Than 1 CFMLin Ft. L Rating At 400°F - Less Than 1 CFMLin Ft. Joint Width - 3/4 in. Max. Includes diagrams and a table of ratings for ANSUL 2079 and CANULC S115.

Classified by Underwriters Laboratories, Inc. to ANSIUL 2079 and CANULC S115. System No. BW-S-0028. Assembly Ratings - 1 and 2 Hr (See Item 2). I Rating At Ambient - Less Than 1 CFMLin Ft. L Rating At 400°F - Less Than 1 CFMLin Ft. Normal Joint Width - 25 mm. L Rating at Ambient - Less Than 1 CFMLin Ft. L Rating at 400°F - Less Than 1 CFMLin Ft. Includes diagrams and a table of ratings for ANSUL 2079 and CANULC S115.

Classified by Underwriters Laboratories, Inc. to ANSIUL 2079. System No. BW-S-0017. Assembly Ratings - 3 and 4 Hr (See Item 2). Joint Width - 3/4 in. (19 mm) Max. Includes diagrams and a table of ratings for ANSUL 2079 and CANULC S115.

Classified by Underwriters Laboratories, Inc. to ANSIUL 2079. System No. BW-S-0020. Assembly Ratings - 1 and 2 Hr (See Item 2). I Rating At Ambient - Less Than 1 CFMLin Ft. L Rating At 400°F - Less Than 1 CFMLin Ft. Includes diagrams and a table of ratings for ANSUL 2079 and CANULC S115.

Classified by Underwriters Laboratories, Inc. to ANSIUL 2079. System No. FW-D-1006. Assembly Rating - 3 Hr. Normal Joint Width - 4 in. I Rating At Ambient - Less Than 1 CFMLin Ft. L Rating At 400°F - Less Than 1 CFMLin Ft. Class II Movement Capabilities - 15% Compression or Extension. Includes diagrams and a table of ratings for ANSUL 2079 and CANULC S115.

Classified by Underwriters Laboratories, Inc. to ANSIUL 2079. System No. BW-S-0003. Assembly Ratings - 1 and 2 Hr (See Item 2). I Rating At Ambient - Less Than 1 CFMLin Ft. L Rating At 400°F - Less Than 1 CFMLin Ft. Joint Width - 3/4 in. Max. Includes diagrams and a table of ratings for ANSUL 2079 and CANULC S115.

Classified by Underwriters Laboratories, Inc. to ANSIUL 2079. System No. BW-S-0017. Assembly Ratings - 3 and 4 Hr (See Item 2). Joint Width - 3/4 in. (19 mm) Max. Includes diagrams and a table of ratings for ANSUL 2079 and CANULC S115.

Classified by Underwriters Laboratories, Inc. to ANSIUL 2079. System No. BW-S-0020. Assembly Ratings - 1 and 2 Hr (See Item 2). I Rating At Ambient - Less Than 1 CFMLin Ft. L Rating At 400°F - Less Than 1 CFMLin Ft. Includes diagrams and a table of ratings for ANSUL 2079 and CANULC S115.

Classified by Underwriters Laboratories, Inc. to ANSIUL 2079 and CANULC S115. System No. FW-D-1007. Assembly Rating - 3 Hr. Normal Joint Width - 4 in. I Rating At Ambient - Less Than 1 CFMLin Ft. L Rating At 400°F - Less Than 1 CFMLin Ft. Class II Movement Capabilities - 15% Compression or Extension. Includes diagrams and a table of ratings for ANSUL 2079 and CANULC S115.

GENERAL NOTES:

- 1. Refer to section 07 84 00 of the specifications. For Quality Control requirements, refer to the Quality Control portion of the specification.
2. Details shown are typical details. If field conditions do not match requirements of typical details, approved alternate details shall be utilized. Field conditions and dimensions need to be verified for compliance with the details, including but not limited to the following:
- Type and thickness of fire-rated construction. The minimum assembly rating of the firestop assembly shall meet or exceed the highest rating of the adjacent construction.
3. If alternate details matching the field conditions are not available, manufacturer's engineering judgment drawings are acceptable. Engineering Judgments shall follow the International Firestop Council (IFC) Guidelines for Evaluating Firestop Systems Engineering Judgments.
4. References:
- UL Fire Resistance Directory; Current Edition
- NFPA 101 Life Safety Code
- All governing local and regional building codes
5. Firestop System installation must meet requirements of ASTM E-814 (UL 1479), ASTM E1966 (UL 1479), ASTM 1966 (UL 2079), ASTM E2307, or ULC-S115 (as required) in tested assemblies that provide a fire rating equal to that of the surrounding construction.

- DIVISION 4: Masonry
DIVISION 7: Thermal & Moisture Protection
DIVISION 9: Finishes
DIVISION 22: Plumbing
DIVISION 23: HVAC
DIVISION 26: Electrical
DIVISION 27: Communications

PROJECT NAME: PROJECT_NAME
PROJECT LOCATION: PROJECT_LOCATION
ARCHITECT/CONSULTANT: ARCHITECT/CONSULTANT
TITLE: STI FIRESTOP SYSTEMS
Specified Technologies Inc.
210 Evans Way Somerville, NJ 08876
Toll Free: (800)992-1180
Phone: (908)526-8000
FAX (908)231-8415
E-Mail:techserv@stifirestop.com
Website:www.stifirestop.com

INDEX

Classified by Underwriters Laboratories, Inc. to ANSIUL 2079

System No. WW-S-0002
 Assembly Rating - 1, 2, 3 and 4 H (See Items 2 and 3B)
 Joint Width - 1 in.
 L Rating At Ambient - Less Than 1 CFM/Lin Ft
 L Rating At 400° F - Less Than 1 CFM/Lin Ft

1. **Wall Assembly** - The 1, 2, 3 or 4 fire-rated gypsum board/stud wall assembly shall be constructed of the materials and in the manner described in the individual U400 or V400 Series Wall and Partition Design in the UL Fire Resistance Directory and shall include the following construction features:
A. Studs - Steel studs to be min 3-1/2 in. (89 mm) wide by 1-1/4 in. (32 mm) deep corrosion protected min 25 MBSG steel channels. Stud spacing not to exceed 24 in. (610 mm) OC. Stud installed normally centered at joint location.
B. Gypsum Board - Gypsum board shall be installed to a min total thickness of 5/8 in. (16 mm), 1-1/4 in. (32 mm), 1-1/2 in. (38 mm) or 2 in. (51 mm) on each side of wall for 1, 2, 3 and 4 hr fire rated assemblies, respectively. Wall to be constructed in the individual U400 or V400 Series Wall and Partition Design in the UL Fire Resistance Directory.
 The hourly rating of the joint system is dependent on the hourly fire rating of the wall assembly in which it is installed.
2. Wall Assembly - Min 6 in. (152 mm) thick steel-reinforced lightweight or normal weight (100-150 pcf or 1600-2400 kg/m³) structural concrete. When the hourly rating is greater than 3 hr, the min thickness of the wall shall be 7-5/8 in. (194 mm) Wall may also be constructed of any UL Classified Concrete Blocks*.
 See **Concrete Blocks (CAZT)** category in the Fire Resistance Directory for names of manufacturers.
3. Joint System - Max width of joint is 1 in. (25 mm). The joint system consists of the following:
A. Forming Material - (Optional, Not Shown) - 1/2, 3/4 or 4 hr fire rated wall assemblies, polyethylene backed rod, mineral wool batt insulation or fiberglass batt insulation friction fit into joint opening. Flush with both surfaces of wall.
B. Fill Void or Cavity Material - Sealant - 1/2 in. fire rated wall assemblies, min 5/8 in. (16 mm) thickness of fill material applied within joint opening. In 2, 3 or 4 hr fire rated wall assemblies, min 1 in. (25 mm) thickness of fill material applied within joint opening. Sealant applied to both sides of wall. Flush with both surfaces of wall.
SPECIFIED TECHNOLOGIES INC. - Speed Free Track Top Gasket
Model: SpecSeal AS Elastomeric Firestop Spray
FILL VOID OR CAVITY MATERIAL: Apply minimum 1/8 in. (wet film thickness) thick layer of fill material over fire resistive joint system ensuring minimum 2 in. overlap onto fireproof coating (Item 3) and minimum 1/2 in. onto face of gypsum wall assembly (Item 1).
 *Indicates such products shall bear the UL or cUL Certification Mark for jurisdictions employing the UL or cUL Certification (such as Canada), respectively.

Reproduced courtesy of Underwriters Laboratories, Inc.
 Created or Revised: January 22, 2014
 (800)992-1180 • (908)231-8000 • FAX (908)231-8415 • E-Mail:techserv@stfirestop.com • Website:www.stfirestop.com
 STI-FF-120-01
 WW-S-0002
 PAGE 1 OF 2

Classified by Underwriters Laboratories, Inc. to ANSIUL 2079 and CANULC S115

System No. WW-S-0063
 ANSUL 2079 CANULC S115
 Assembly Rating: 1 and 2 H (See Item 2) F Ratings: 1 and 2 H (See Item 2)
 Nominal Joint Width: 1 in. (25 mm) FT Ratings: 1 and 2 H (See Item 2)
 L Rating at Ambient: Less Than 1 CFM/Lin Ft FTH Ratings: 1 and 2 H (See Item 2)
 L Rating at 400° F: Less Than 1 CFM/Lin Ft FTH Ratings: 1 and 2 H (See Item 2)
 Nominal Joint Width: 25 mm
 L Rating at Ambient: Less Than 1 CFM/Lin Ft
 L Rating at 400° F: Less Than 1 CFM/Lin Ft

1. **Wall Assembly** - Min 6 in. (152 mm) thick reinforced lightweight or normal weight (100-150 pcf or 1600-2400 kg/m³) structural concrete. Additionally, thickness of concrete wall shall be equal to or greater than thickness of gypsum board wall. Wall may also be constructed of any UL Classified Concrete Blocks*.
 See **Concrete Blocks (CAZT)** category in the Fire Resistance Directory for names of manufacturers.
2. Wall Assembly - The 1 or 2 hr fire-rated gypsum board/stud wall assembly shall be constructed of the materials and in the manner described in the individual U400, V400 or W400 Series Wall and Partition Design in the UL Fire Resistance Directory and shall include the following construction features:
A. Studs - Steel studs to be min 3-1/2 in. (89 mm) wide. Stud spacing not to exceed 24 in. (610 mm) OC.

Reproduced courtesy of Underwriters Laboratories, Inc.
 Created or Revised: January 22, 2014
 (800)992-1180 • (908)231-8000 • FAX (908)231-8415 • E-Mail:techserv@stfirestop.com • Website:www.stfirestop.com
 STI-FF-120-01
 WW-S-0063
 PAGE 1 OF 2

Classified by Underwriters Laboratories, Inc. to ANSIUL 2079

System No. WW-S-0064
 ANSUL 2079 CANULC S115
 Assembly Rating: 1 and 2 H (See Item 2) F Ratings: 1 and 2 H (See Item 2)
 Nominal Joint Width: 3/4 in. FT Ratings: 1 and 2 H (See Item 2)
 L Rating at Ambient: Less Than 1 CFM/Lin Ft FTH Ratings: 1 and 2 H (See Item 2)
 L Rating at 400° F: Less Than 1 CFM/Lin Ft FTH Ratings: 1 and 2 H (See Item 2)
 Nominal Joint Width: 19 mm
 L Rating at Ambient: Less Than 1 CFM/Lin Ft
 L Rating at 400° F: Less Than 1 CFM/Lin Ft

1. **Wall Assembly** - Min 6 in. (152 mm) thick reinforced lightweight or normal weight (100-150 pcf or 1600-2400 kg/m³) structural concrete. Additionally, thickness of concrete wall shall be equal to or greater than thickness of gypsum board wall. Wall may also be constructed of any UL Classified Concrete Blocks*.
 See **Concrete Blocks (CAZT)** category in the Fire Resistance Directory for names of manufacturers.
2. Wall Assembly - The 1 or 2 hr fire-rated gypsum board/stud wall assembly shall be constructed of the materials and in the manner described in the individual U400, V400 or W400 Series Wall and Partition Design in the UL Fire Resistance Directory and shall include the following construction features:
A. Studs - Steel studs to be min 3-1/2 in. (89 mm) wide. Stud spacing not to exceed 24 in. (610 mm) OC.

Reproduced courtesy of Underwriters Laboratories, Inc.
 Created or Revised: January 22, 2014
 (800)992-1180 • (908)231-8000 • FAX (908)231-8415 • E-Mail:techserv@stfirestop.com • Website:www.stfirestop.com
 STI-FF-120-01
 WW-S-0064
 PAGE 1 OF 2

Classified by Underwriters Laboratories, Inc. to ANSIUL 2079

System No. WW-D-0004
 Assembly Rating: 2 H
 Nominal Joint Width: 4 in.
 L Rating At Ambient: Less Than 1 CFM/Lin Ft
 L Rating At 400° F: Less Than 1 CFM/Lin Ft
 Class II Movement Capabilities - 15% Compression or Extension

1. **Wall Assembly** - Min 4-1/2 in. (114 mm) thick reinforced lightweight or normal weight (100-150 pcf or 1600-2400 kg/m³) structural concrete. Wall may also be constructed of any UL Classified Concrete Blocks*.
 See **Concrete Blocks (CAZT)** category in the Fire Resistance Directory for names of manufacturers.
2. Joint System - Max width of joint (at time of installation of joint system) is 4 in. (102 mm). The joint system is designed to accommodate a max 15 percent compression or extension from it's installed width. The joint system shall consist of the following:
A. Forming Material - Min 4 pcf (64 kg/m³) mineral wool batt insulation installed in joint opening as a permanent form. Pieces of batt cut to min width of 4 in. (102 mm) and installed edge first into joint opening, parallel with joint direction, such that batt sections are compressed min 33 percent in thickness and that the compressed batt sections are recessed from each surface of the wall as required to accommodate the required thickness of fill material. Adjoining lengths of batt to be lightly-butted with butted seams spaced min 16 in. (406 mm) apart along the length of the joint.
B. Fill Void or Cavity Material - Sealant - Min 1/2 in. (13 mm) thickness of fill material applied within the joint. Flush with both surfaces of wall.
SPECIFIED TECHNOLOGIES INC. - SpecSeal ES Sealant
 *Indicates such products shall bear the UL or cUL Certification Mark for jurisdictions employing the UL or cUL Certification (such as Canada), respectively.

Reproduced courtesy of Underwriters Laboratories, Inc.
 Created or Revised: January 22, 2014
 (800)992-1180 • (908)231-8000 • FAX (908)231-8415 • E-Mail:techserv@stfirestop.com • Website:www.stfirestop.com
 STI-FF-120-01
 WW-D-0004
 PAGE 1 OF 2

Classified by Underwriters Laboratories, Inc. to ANSIUL 2079

System No. WW-D-0004
 Assembly Rating: 2 H
 Nominal Joint Width: 4 in.
 L Rating At Ambient: Less Than 1 CFM/Lin Ft
 L Rating At 400° F: Less Than 1 CFM/Lin Ft
 Class II Movement Capabilities - 15% Compression Or Extension

1. **Wall Assembly** - Min 4-1/2 in. (114 mm) thick reinforced lightweight or normal weight (100-150 pcf or 1600-2400 kg/m³) structural concrete. Wall may also be constructed of any UL Classified Concrete Blocks*.
 See **Concrete Blocks (CAZT)** category in the Fire Resistance Directory for names of manufacturers.
2. Joint System - Max width of joint (at time of installation of joint system) is 4 in. (102 mm). The joint system is designed to accommodate a max 15 percent compression or extension from it's installed width. The joint system shall consist of the following:
A. Forming Material - Min 4 pcf (64 kg/m³) mineral wool batt insulation installed in joint opening as a permanent form. Pieces of batt cut to min width of 4 in. (102 mm) and installed edge first into joint opening, parallel with joint direction, such that batt sections are compressed min 33 percent in thickness and that the compressed batt sections are recessed from each surface of the wall as required to accommodate the required thickness of fill material. Adjoining lengths of batt to be lightly-butted with butted seams spaced min 16 in. (406 mm) apart along the length of the joint.
B. Fill Void or Cavity Material - Sealant - Min 1/2 in. (13 mm) thickness of fill material applied within the joint. Flush with both surfaces of wall.
SPECIFIED TECHNOLOGIES INC. - SpecSeal ES Sealant
 *Indicates such products shall bear the UL or cUL Certification Mark for jurisdictions employing the UL or cUL Certification (such as Canada), respectively.

Reproduced courtesy of Underwriters Laboratories, Inc.
 Created or Revised: January 22, 2014
 (800)992-1180 • (908)231-8000 • FAX (908)231-8415 • E-Mail:techserv@stfirestop.com • Website:www.stfirestop.com
 STI-FF-120-01
 WW-D-0004
 PAGE 1 OF 2

Classified by Underwriters Laboratories, Inc. to ANSIUL 2079

System No. WW-D-0004
 Assembly Rating: 2 H
 Nominal Joint Width: 4 in.
 L Rating At Ambient: Less Than 1 CFM/Lin Ft
 L Rating At 400° F: Less Than 1 CFM/Lin Ft
 Class II Movement Capabilities - 15% Compression or Extension

1. **Wall Assembly** - Min 4-1/2 in. (114 mm) thick reinforced lightweight or normal weight (100-150 pcf or 1600-2400 kg/m³) structural concrete. Wall may also be constructed of any UL Classified Concrete Blocks*.
 See **Concrete Blocks (CAZT)** category in the Fire Resistance Directory for names of manufacturers.
2. Joint System - Max width of joint (at time of installation of joint system) is 4 in. (102 mm). The joint system is designed to accommodate a max 15 percent compression or extension from it's installed width. The joint system shall consist of the following:
A. Forming Material - Min 4 pcf (64 kg/m³) mineral wool batt insulation installed in joint opening as a permanent form. Pieces of batt cut to min width of 4 in. (102 mm) and installed edge first into joint opening, parallel with joint direction, such that batt sections are compressed min 33 percent in thickness and that the compressed batt sections are recessed from each surface of the wall as required to accommodate the required thickness of fill material. Adjoining lengths of batt to be lightly-butted with butted seams spaced min 16 in. (406 mm) apart along the length of the joint.
B. Fill Void or Cavity Material - Sealant - Min 1/2 in. (13 mm) thickness of fill material applied within the joint. Flush with both surfaces of wall.
SPECIFIED TECHNOLOGIES INC. - SpecSeal AS Elastomeric Spray
 *Indicates such products shall bear the UL or cUL Certification Mark for jurisdictions employing the UL or cUL Certification (such as Canada), respectively.

Reproduced courtesy of Underwriters Laboratories, Inc.
 Created or Revised: January 22, 2014
 (800)992-1180 • (908)231-8000 • FAX (908)231-8415 • E-Mail:techserv@stfirestop.com • Website:www.stfirestop.com
 STI-FF-120-01
 WW-D-0004
 PAGE 1 OF 2

Classified by Underwriters Laboratories, Inc. to ANSIUL 2079 and CANULC S115

System No. WW-S-0064
 ANSUL 2079 CANULC S115
 Assembly Rating: 1 and 2 H (See Item 2) F Ratings: 1 and 2 H (See Item 2)
 Nominal Joint Width: 3/4 in. FT Ratings: 1 and 2 H (See Item 2)
 L Rating at Ambient: Less Than 1 CFM/Lin Ft FTH Ratings: 1 and 2 H (See Item 2)
 L Rating at 400° F: Less Than 1 CFM/Lin Ft FTH Ratings: 1 and 2 H (See Item 2)
 Nominal Joint Width: 19 mm
 L Rating at Ambient: Less Than 1 CFM/Lin Ft
 L Rating at 400° F: Less Than 1 CFM/Lin Ft

1. **Wall Assembly** - Min 6 in. (152 mm) thick reinforced lightweight or normal weight (100-150 pcf or 1600-2400 kg/m³) structural concrete. Additionally, thickness of concrete wall shall be equal to or greater than thickness of gypsum board wall. Wall may also be constructed of any UL Classified Concrete Blocks*.
 See **Concrete Blocks (CAZT)** category in the Fire Resistance Directory for names of manufacturers.
2. Wall Assembly - The 1 or 2 hr fire-rated gypsum board/stud wall assembly shall be constructed of the materials and in the manner described in the individual U400, V400 or W400 Series Wall and Partition Design in the UL Fire Resistance Directory and shall include the following construction features:
A. Steel Runner - Z-shaped runners, min 4 in. (102 mm) deep, with unequal legs of 1 in. (25 mm) and 2 in. (51 mm), fabricated from min 24 MBSG galv steel. Runners positioned with short leg toward finished side of wall. Runners attached to structural supports with steel fasteners located not greater than 2 in. (51 mm) from ends and not greater than 24 in. (610 mm) OC.

Reproduced courtesy of Underwriters Laboratories, Inc.
 Created or Revised: October 20, 2015
 (800)992-1180 • (908)231-8000 • FAX (908)231-8415 • E-Mail:techserv@stfirestop.com • Website:www.stfirestop.com
 STI-FF-120-01
 WW-S-0064
 PAGE 1 OF 2

Classified by Underwriters Laboratories, Inc. to ANSIUL 2079

System No. WW-D-0004
 Assembly Rating: 2 H
 Nominal Joint Width: 4 in.
 L Rating At Ambient: Less Than 1 CFM/Lin Ft
 L Rating At 400° F: Less Than 1 CFM/Lin Ft
 Class II Movement Capabilities - 15% Compression Or Extension

1. **Wall Assembly** - Min 4-1/2 in. (114 mm) thick reinforced lightweight or normal weight (100-150 pcf or 1600-2400 kg/m³) structural concrete. Wall may also be constructed of any UL Classified Concrete Blocks*.
 See **Concrete Blocks (CAZT)** category in the Fire Resistance Directory for names of manufacturers.
2. Joint System - Max width of joint (at time of installation of joint system) is 4 in. (102 mm). The joint system is designed to accommodate a max 15 percent compression or extension from it's installed width. The joint system shall consist of the following:
A. Forming Material - Min 4 pcf (64 kg/m³) mineral wool batt insulation installed in joint opening as a permanent form. Pieces of batt cut to min width of 4 in. (102 mm) and installed edge first into joint opening, parallel with joint direction, such that batt sections are compressed min 33 percent in thickness and that the compressed batt sections are recessed from each surface of the wall as required to accommodate the required thickness of fill material. Adjoining lengths of batt to be lightly-butted with butted seams spaced min 16 in. (406 mm) apart along the length of the joint.
B. Fill Void or Cavity Material - Sealant - Min 1/2 in. (13 mm) thickness of fill material applied within the joint. Flush with both surfaces of wall.
SPECIFIED TECHNOLOGIES INC. - SpecSeal ES Sealant
 *Indicates such products shall bear the UL or cUL Certification Mark for jurisdictions employing the UL or cUL Certification (such as Canada), respectively.

Reproduced courtesy of Underwriters Laboratories, Inc.
 Created or Revised: January 22, 2014
 (800)992-1180 • (908)231-8000 • FAX (908)231-8415 • E-Mail:techserv@stfirestop.com • Website:www.stfirestop.com
 STI-FF-120-01
 WW-D-0004
 PAGE 1 OF 2

Classified by Underwriters Laboratories, Inc. to ANSIUL 2079

System No. WW-D-0004
 Assembly Rating: 2 H
 Nominal Joint Width: 4 in.
 L Rating At Ambient: Less Than 1 CFM/Lin Ft
 L Rating At 400° F: Less Than 1 CFM/Lin Ft
 Class II Movement Capabilities - 15% Compression Or Extension

1. **Wall Assembly** - Min 4-1/2 in. (114 mm) thick reinforced lightweight or normal weight (100-150 pcf or 1600-2400 kg/m³) structural concrete. Wall may also be constructed of any UL Classified Concrete Blocks*.
 See **Concrete Blocks (CAZT)** category in the Fire Resistance Directory for names of manufacturers.
2. Joint System - Max width of joint (at time of installation of joint system) is 4 in. (102 mm). The joint system is designed to accommodate a max 15 percent compression or extension from it's installed width. The joint system shall consist of the following:
A. Forming Material - Min 4 pcf (64 kg/m³) mineral wool batt insulation installed in joint opening as a permanent form. Pieces of batt cut to min width of 4 in. (102 mm) and installed edge first into joint opening, parallel with joint direction, such that batt sections are compressed min 33 percent in thickness and that the compressed batt sections are recessed from each surface of the wall as required to accommodate the required thickness of fill material. Adjoining lengths of batt to be lightly-butted with butted seams spaced min 16 in. (406 mm) apart along the length of the joint.
B. Fill Void or Cavity Material - Sealant - Min 1/2 in. (13 mm) thickness of fill material applied within the joint. Flush with both surfaces of wall.
SPECIFIED TECHNOLOGIES INC. - SpecSeal ES Sealant
 *Indicates such products shall bear the UL or cUL Certification Mark for jurisdictions employing the UL or cUL Certification (such as Canada), respectively.

Reproduced courtesy of Underwriters Laboratories, Inc.
 Created or Revised: January 22, 2014
 (800)992-1180 • (908)231-8000 • FAX (908)231-8415 • E-Mail:techserv@stfirestop.com • Website:www.stfirestop.com
 STI-FF-120-01
 WW-D-0004
 PAGE 1 OF 2

Classified by Underwriters Laboratories, Inc. to ANSIUL 2079

System No. WW-D-0004
 Assembly Rating: 2 H
 Nominal Joint Width: 4 in.
 L Rating At Ambient: Less Than 1 CFM/Lin Ft
 L Rating At 400° F: Less Than 1 CFM/Lin Ft
 Class II Movement Capabilities - 15% Compression Or Extension

1. **Wall Assembly** - Min 4-1/2 in. (114 mm) thick reinforced lightweight or normal weight (100-150 pcf or 1600-2400 kg/m³) structural concrete. Wall may also be constructed of any UL Classified Concrete Blocks*.
 See **Concrete Blocks (CAZT)** category in the Fire Resistance Directory for names of manufacturers.
2. Joint System - Max width of joint (at time of installation of joint system) is 4 in. (102 mm). The joint system is designed to accommodate a max 15 percent compression or extension from it's installed width. The joint system shall consist of the following:
A. Forming Material - Min 4 pcf (64 kg/m³) mineral wool batt insulation installed in joint opening as a permanent form. Pieces of batt cut to min width of 4 in. (102 mm) and installed edge first into joint opening, parallel with joint direction, such that batt sections are compressed min 33 percent in thickness and that the compressed batt sections are recessed from each surface of the wall as required to accommodate the required thickness of fill material. Adjoining lengths of batt to be lightly-butted with butted seams spaced min 16 in. (406 mm) apart along the length of the joint.
B. Fill Void or Cavity Material - Sealant - Min 1/2 in. (13 mm) thickness of fill material applied within the joint. Flush with both surfaces of wall.
SPECIFIED TECHNOLOGIES INC. - SpecSeal AS Elastomeric Spray
 *Indicates such products shall bear the UL or cUL Certification Mark for jurisdictions employing the UL or cUL Certification (such as Canada), respectively.

Reproduced courtesy of Underwriters Laboratories, Inc.
 Created or Revised: January 22, 2014
 (800)992-1180 • (908)231-8000 • FAX (908)231-8415 • E-Mail:techserv@stfirestop.com • Website:www.stfirestop.com
 STI-FF-120-01
 WW-D-0004
 PAGE 1 OF 2

Classified by Underwriters Laboratories, Inc. to ANSIUL 2079

System No. WW-D-0004
 Assembly Rating: 2 H
 Nominal Joint Width: 4 in.
 L Rating At Ambient: Less Than 1 CFM/Lin Ft
 L Rating At 400° F: Less Than 1 CFM/Lin Ft
 Class II Movement Capabilities - 15% Compression Or Extension

1. **Wall Assembly** - Min 4-1/2 in. (114 mm) thick reinforced lightweight or normal weight (100-150 pcf or 1600-2400 kg/m³) structural concrete. Wall may also be constructed of any UL Classified Concrete Blocks*.
 See **Concrete Blocks (CAZT)** category in the Fire Resistance Directory for names of manufacturers.
2. Joint System - Max width of joint (at time of installation of joint system) is 4 in. (102 mm). The joint system is designed to accommodate a max 15 percent compression or extension from it's installed width. The joint system shall consist of the following:
A. Forming Material - Min 4 pcf (64 kg/m³) mineral wool batt insulation installed in joint opening as a permanent form. Pieces of batt cut to min width of 4 in. (102 mm) and installed edge first into joint opening, parallel with joint direction, such that batt sections are compressed min 33 percent in thickness and that the compressed batt sections are recessed from each surface of the wall as required to accommodate the required thickness of fill material. Adjoining lengths of batt to be lightly-butted with butted seams spaced min 16 in. (406 mm) apart along the length of the joint.
B. Fill Void or Cavity Material - Sealant - Min 1/2 in. (13 mm) thickness of fill material applied within the joint. Flush with both surfaces of wall.
SPECIFIED TECHNOLOGIES INC. - SpecSeal AS Elastomeric Spray
 *Indicates such products shall bear the UL or cUL Certification Mark for jurisdictions employing the UL or cUL Certification (such as Canada), respectively.

Reproduced courtesy of Underwriters Laboratories, Inc.
 Created or Revised: January 22, 2014
 (800)992-1180 • (908)231-8000 • FAX (908)231-8415 • E-Mail:techserv@stfirestop.com • Website:www.stfirestop.com
 STI-FF-120-01
 WW-D-0004
 PAGE 1 OF 2

GENERAL NOTES:

1. Refer to section 07 84 00 of the specifications. For Quality Control requirements, refer to the Quality Control portion of the specification.
2. Details shown are typical details. If field conditions do not match requirements of typical details, approved alternate details shall be utilized. Field conditions and dimensions need to be verified for compliance with the details, including but not limited to the following:
 - Type and thickness of fire-rated construction. The minimum assembly rating of the firestop assembly shall meet or exceed the highest rating of the adjacent construction.
3. If alternate details matching the field conditions are not available, manufacturer's engineering judgment drawings are acceptable. Engineering Judgments shall follow the International Firestop Council (IFC) Guidelines for Evaluating Firestop Systems Engineering Judgments.
4. References:
 - UL Fire Resistance Directory; Current Edition
 - NFPA 101 Life Safety Code
 - All governing local and regional building codes
5. Firestop System installation must meet requirements of ASTM E-814 (UL 1479), ASTM E1966 (UL 1479), ASTM 1966 (UL 2079), ASTM E2307, or ULC-S115 (as required) in tested assemblies that provide a fire rating equal to that of the surrounding construction.

- DIVISION 4: Masonry
 DIVISION 7: Thermal & Moisture Protection
 DIVISION 9: Finishes
 DIVISION 22: Plumbing
 DIVISION 23: HVAC
 DIVISION 26: Electrical
 DIVISION 27: Communications

PROJECT NAME:

PROJECT_NAME:

PROJECT LOCATION:

PROJECT_LOCATION:

ARCHITECT/CONSULTANT:


ARCHITECT/CONSULTANT:

TITLE:

STI FIRESTOP SYSTEMS

Specified Technologies Inc.
 210 Evans Way Somerville, NJ 08876

Toll Free: (800)992-1180
 Phone: (908)526-8000
 FAX (908)231-8415
 E-Mail:techserv@stfirestop.com
 Website:www.stfirestop.com



INDEX

Specified Technologies, Inc. Design No. STI/BFP 120-04. Primer Fire Barrier System SpecSeal® Window Wall Gasket, SpecSeal® SIL300 Silicone Sealant. ASTM E2307, ANSI/CES 5115, Rating: F-Rating - 2 hr, T-Rating - 1 hr. Includes diagrams and product details.

Specified Technologies, Inc. Design No. STI/BFP 120-04. Includes diagrams and product details for various fire barrier components.

Specified Technologies, Inc. Design No. STI/BFP 120-04. Includes diagrams and product details for fire barrier systems.

System No. CW-D-1007. F Rating - 144 Hr. L Rating At Ambient - Less Than 1 CFM/Lin Ft. Includes diagrams and product details.

Specified Technologies, Inc. Design No. STI/BFP 120-04. Includes diagrams and product details for fire barrier systems.

System No. CW-D-2076. F Rating - 0 Hr. L Rating - 0 Hr. Includes diagrams and product details.

Specified Technologies, Inc. Design No. STI/BFP 120-04. Includes diagrams and product details for fire barrier systems.

System No. C-AJ-1353. F Rating - 3 Hr. L Rating At Ambient - Less Than 1 CFM/Lin Ft. Includes diagrams and product details.

Specified Technologies, Inc. Design No. STI/BFP 120-04. Includes diagrams and product details for fire barrier systems.

System No. C-AJ-1361. F Rating - 2 Hr. T Rating - 0 and 1 Hr. Includes diagrams and product details.

Specified Technologies, Inc. Design No. STI/BFP 120-04. Includes diagrams and product details for fire barrier systems.

System No. C-AJ-1353. F Rating - 3 Hr. L Rating At Ambient - Less Than 1 CFM/Lin Ft. Includes diagrams and product details.

GENERAL NOTES:

- 1. Refer to section 07 84 00 of the specifications. For Quality Control requirements, refer to the Quality Control portion of the specification.
2. Details shown are typical details. If field conditions do not match requirements of typical details, approved alternate details shall be utilized. Field conditions and dimensions need to be verified for compliance with the details, including but not limited to the following:
- Type and thickness of fire-rated construction. The minimum assembly rating of the firestop assembly shall meet or exceed the highest rating of the adjacent construction.
3. If alternate details matching the field conditions are not available, manufacturer's engineering judgment drawings are acceptable. Engineering Judgments shall follow the International Firestop Council (IFC) Guidelines for Evaluating Firestop Systems Engineering Judgments.
4. References:
- UL Fire Resistance Directory; Current Edition
- NFPA 101 Life Safety Code
- All governing local and regional building codes
5. Firestop System installation must meet requirements of ASTM E-814 (UL 1479), ASTM E1966 (UL 1479), ASTM 1966 (UL 2079), ASTM E2307, or ULC-S115 (as required) in tested assemblies that provide a fire rating equal to that of the surrounding construction.

DIVISION 4: Masonry
DIVISION 7: Thermal & Moisture Protection
DIVISION 9: Finishes
DIVISION 22: Plumbing
DIVISION 23: HVAC
DIVISION 26: Electrical
DIVISION 27: Communications
PROJECT NAME:
PROJECT LOCATION:
ARCHITECT/CONSULTANT:
ARCHITECT/CONSULTANT:
TITLE:
STI FIRESTOP SYSTEMS
Specified Technologies Inc.
210 Evans Way Somerville, NJ 08876
Toll Free: (800)992-1180
Phone: (908)526-8000
FAX (908)231-8415
E-Mail: techserv@stifirestop.com
Website: www.stifirestop.com

INDEX

System No. W-L-1049
Classified by Underwriters Laboratories, Inc. to ANSUL 1479 (ASTM E814) and CANULC S115
ANSUL 1479 (ASTM E814) CANULC S115
F Ratings - 1 and 2 Hr (See Item 1) F Rating - 1 and 2 Hr (See Item 1)
T Rating - 0 Hr FT Rating - 0 Hr
L Rating At Ambient - Less Than 1 CFMsq Ft FH Rating - 1 and 2 Hr (See Item 1)
L Rating At 400 F - Less Than 1 CFMsq Ft FTH Rating - 0 Hr
L Rating At Ambient - Less Than 1 CFMsq Ft L Rating At Ambient - Less Than 1 CFMsq Ft
L Rating At 400 F - Less Than 1 CFMsq Ft L Rating At 400 F - Less Than 1 CFMsq Ft

System No. W-L-1168
Classified by Underwriters Laboratories, Inc. to ANSUL 1479 (ASTM E814) and CANULC S115
ANSUL 1479 (ASTM E814) CANULC S115
F Ratings - 1 and 2 Hr (See Item 1) F Ratings - 1 and 2 Hr (See Item 1)
T Ratings - 1/4, 3/4 and 1 Hr (See Items 2 and 4) FT Ratings - 1/4, 3/4 and 1 Hr (See Items 2 and 4)
L Rating At Ambient - Less Than 1 CFMsq Ft FH Ratings - 1/4, 3/4 and 1 Hr (See Items 2 and 4)
L Rating At 400 F - Less Than 1 CFMsq Ft FTH Ratings - 1/4, 3/4 and 1 Hr (See Items 2 and 4)
L Rating At Ambient - Less Than 1 CFMsq Ft L Rating At Ambient - Less Than 1 CFMsq Ft
L Rating At 400 F - Less Than 1 CFMsq Ft L Rating At 400 F - Less Than 1 CFMsq Ft

System No. C-AJ-5087
Classified by Underwriters Laboratories, Inc. to ANSUL 1479 (ASTM E814) and CANULC S115
ANSUL 1479 (ASTM E814) CANULC S115
F Rating - 2 Hr F Rating - 2 Hr
T Rating - 1 Hr FT Rating - 1 Hr
L Rating At Ambient - Less Than 1 CFMsq Ft FH Rating - 1 Hr
L Rating At 400 F - Less Than 1 CFMsq Ft FTH Rating - 1 Hr
L Rating At Ambient - Less Than 1 CFMsq Ft L Rating At Ambient - Less Than 1 CFMsq Ft
L Rating At 400 F - Less Than 1 CFMsq Ft L Rating At 400 F - Less Than 1 CFMsq Ft

System No. C-AJ-5155
Classified by Underwriters Laboratories, Inc. to ANSUL 1479 (ASTM E814)
F Rating - 2 Hr
T Rating - 3/4 Hr

System No. F-A-5041
Classified by Underwriters Laboratories, Inc. to ANSUL 1479 (ASTM E814) and CANULC S115
ANSUL 1479 (ASTM E814) CANULC S115
F Ratings - 2 and 3 Hr (See Items 1 and 1A) F Ratings - 2 and 3 Hr (See Items 1 and 1A)
T Ratings - 3/4 and 1 Hr (See Item 3) FT Rating - 3/4 and 1 Hr (See Item 3)
L Rating At Ambient - Less Than 1 CFMsq Ft FH Ratings - 2 and 3 Hr (See Items 1 and 1A)
L Rating At 400 F - Less Than 1 CFMsq Ft FTH Rating - 3/4 and 1 Hr (See Item 3)
W Rating - Class 1 (See Items 4A, 5 and 7) L Rating At Ambient - Less Than 5.1 L/hr/2 (See Items 5 and 7)
L Rating At 400 F - Less Than 5.1 L/hr/2 (See Items 5 and 7)

System No. F-A-5041 (continued)
Classified by Underwriters Laboratories, Inc. to ANSUL 1479 (ASTM E814) and CANULC S115
ANSUL 1479 (ASTM E814) CANULC S115
F Ratings - 2 and 3 Hr (See Items 1 and 1A) F Ratings - 2 and 3 Hr (See Items 1 and 1A)
T Ratings - 3/4 and 1 Hr (See Item 3) FT Rating - 3/4 and 1 Hr (See Item 3)
L Rating At Ambient - Less Than 1 CFMsq Ft FH Ratings - 2 and 3 Hr (See Items 1 and 1A)
L Rating At 400 F - Less Than 1 CFMsq Ft FTH Rating - 3/4 and 1 Hr (See Item 3)
W Rating - Class 1 (See Items 4A, 5 and 7) L Rating At Ambient - Less Than 5.1 L/hr/2 (See Items 5 and 7)
L Rating At 400 F - Less Than 5.1 L/hr/2 (See Items 5 and 7)

System No. F-A-5041 (continued)
Classified by Underwriters Laboratories, Inc. to ANSUL 1479 (ASTM E814) and CANULC S115
ANSUL 1479 (ASTM E814) CANULC S115
F Ratings - 2 and 3 Hr (See Items 1 and 1A) F Ratings - 2 and 3 Hr (See Items 1 and 1A)
T Ratings - 3/4 and 1 Hr (See Item 3) FT Rating - 3/4 and 1 Hr (See Item 3)
L Rating At Ambient - Less Than 1 CFMsq Ft FH Ratings - 2 and 3 Hr (See Items 1 and 1A)
L Rating At 400 F - Less Than 1 CFMsq Ft FTH Rating - 3/4 and 1 Hr (See Item 3)
W Rating - Class 1 (See Items 4A, 5 and 7) L Rating At Ambient - Less Than 5.1 L/hr/2 (See Items 5 and 7)
L Rating At 400 F - Less Than 5.1 L/hr/2 (See Items 5 and 7)

System No. F-A-5041 (continued)
Classified by Underwriters Laboratories, Inc. to ANSUL 1479 (ASTM E814) and CANULC S115
ANSUL 1479 (ASTM E814) CANULC S115
F Ratings - 2 and 3 Hr (See Items 1 and 1A) F Ratings - 2 and 3 Hr (See Items 1 and 1A)
T Ratings - 3/4 and 1 Hr (See Item 3) FT Rating - 3/4 and 1 Hr (See Item 3)
L Rating At Ambient - Less Than 1 CFMsq Ft FH Ratings - 2 and 3 Hr (See Items 1 and 1A)
L Rating At 400 F - Less Than 1 CFMsq Ft FTH Rating - 3/4 and 1 Hr (See Item 3)
W Rating - Class 1 (See Items 4A, 5 and 7) L Rating At Ambient - Less Than 5.1 L/hr/2 (See Items 5 and 7)
L Rating At 400 F - Less Than 5.1 L/hr/2 (See Items 5 and 7)

System No. F-A-5041 (continued)
Classified by Underwriters Laboratories, Inc. to ANSUL 1479 (ASTM E814) and CANULC S115
ANSUL 1479 (ASTM E814) CANULC S115
F Ratings - 2 and 3 Hr (See Items 1 and 1A) F Ratings - 2 and 3 Hr (See Items 1 and 1A)
T Ratings - 3/4 and 1 Hr (See Item 3) FT Rating - 3/4 and 1 Hr (See Item 3)
L Rating At Ambient - Less Than 1 CFMsq Ft FH Ratings - 2 and 3 Hr (See Items 1 and 1A)
L Rating At 400 F - Less Than 1 CFMsq Ft FTH Rating - 3/4 and 1 Hr (See Item 3)
W Rating - Class 1 (See Items 4A, 5 and 7) L Rating At Ambient - Less Than 5.1 L/hr/2 (See Items 5 and 7)
L Rating At 400 F - Less Than 5.1 L/hr/2 (See Items 5 and 7)

System No. F-A-5041 (continued)
Classified by Underwriters Laboratories, Inc. to ANSUL 1479 (ASTM E814) and CANULC S115
ANSUL 1479 (ASTM E814) CANULC S115
F Ratings - 2 and 3 Hr (See Items 1 and 1A) F Ratings - 2 and 3 Hr (See Items 1 and 1A)
T Ratings - 3/4 and 1 Hr (See Item 3) FT Rating - 3/4 and 1 Hr (See Item 3)
L Rating At Ambient - Less Than 1 CFMsq Ft FH Ratings - 2 and 3 Hr (See Items 1 and 1A)
L Rating At 400 F - Less Than 1 CFMsq Ft FTH Rating - 3/4 and 1 Hr (See Item 3)
W Rating - Class 1 (See Items 4A, 5 and 7) L Rating At Ambient - Less Than 5.1 L/hr/2 (See Items 5 and 7)
L Rating At 400 F - Less Than 5.1 L/hr/2 (See Items 5 and 7)

System No. F-A-5041 (continued)
Classified by Underwriters Laboratories, Inc. to ANSUL 1479 (ASTM E814) and CANULC S115
ANSUL 1479 (ASTM E814) CANULC S115
F Ratings - 2 and 3 Hr (See Items 1 and 1A) F Ratings - 2 and 3 Hr (See Items 1 and 1A)
T Ratings - 3/4 and 1 Hr (See Item 3) FT Rating - 3/4 and 1 Hr (See Item 3)
L Rating At Ambient - Less Than 1 CFMsq Ft FH Ratings - 2 and 3 Hr (See Items 1 and 1A)
L Rating At 400 F - Less Than 1 CFMsq Ft FTH Rating - 3/4 and 1 Hr (See Item 3)
W Rating - Class 1 (See Items 4A, 5 and 7) L Rating At Ambient - Less Than 5.1 L/hr/2 (See Items 5 and 7)
L Rating At 400 F - Less Than 5.1 L/hr/2 (See Items 5 and 7)

System No. F-A-5041 (continued)
Classified by Underwriters Laboratories, Inc. to ANSUL 1479 (ASTM E814) and CANULC S115
ANSUL 1479 (ASTM E814) CANULC S115
F Ratings - 2 and 3 Hr (See Items 1 and 1A) F Ratings - 2 and 3 Hr (See Items 1 and 1A)
T Ratings - 3/4 and 1 Hr (See Item 3) FT Rating - 3/4 and 1 Hr (See Item 3)
L Rating At Ambient - Less Than 1 CFMsq Ft FH Ratings - 2 and 3 Hr (See Items 1 and 1A)
L Rating At 400 F - Less Than 1 CFMsq Ft FTH Rating - 3/4 and 1 Hr (See Item 3)
W Rating - Class 1 (See Items 4A, 5 and 7) L Rating At Ambient - Less Than 5.1 L/hr/2 (See Items 5 and 7)
L Rating At 400 F - Less Than 5.1 L/hr/2 (See Items 5 and 7)

GENERAL NOTES:

- 1. Refer to section 07 84 00 of the specifications. For Quality Control requirements, refer to the Quality Control portion of the specification.
2. Details shown are typical details. If field conditions do not match requirements of typical details, approved alternate details shall be utilized. Field conditions and dimensions need to be verified for compliance with the details, including but not limited to the following:
- Type and thickness of fire-rated construction. The minimum assembly rating of the firestop assembly shall meet or exceed the highest rating of the adjacent construction.
3. If alternate details matching the field conditions are not available, manufacturer's engineering judgment drawings are acceptable. Engineering Judgments shall follow the International Firestop Council (IFC) Guidelines for Evaluating Firestop Systems Engineering Judgments.

- 4. References:
- UL Fire Resistance Directory; Current Edition
- NFPA 101 Life Safety Code
- All governing local and regional building codes
5. Firestop System installation must meet requirements of ASTM E-814 (UL 1479), ASTM E1966 (UL 1479), ASTM 1966 (UL 2079), ASTM E2307, or ULC-S115 (as required) in tested assemblies that provide a fire rating equal to that of the surrounding construction.

DIVISION 4: Masonry Protection
DIVISION 7: Thermal & Moisture Protection
DIVISION 9: Finishes
DIVISION 22: Plumbing
DIVISION 23: HVAC
DIVISION 26: Electrical
DIVISION 27: Communications

PROJECT NAME:

PROJECT_NAME:

PROJECT LOCATION:

PROJECT_LOCATION:

ARCHITECT/CONSULTANT:

ARCHITECT/CONSULTANT:

TITLE: STI FIRESTOP SYSTEMS

Specified Technologies Inc.
210 Evans Way Somerville, NJ 08876

Toll Free: (800)992-1180
Phone: (908)526-8000
FAX (908)231-8415
E-Mail:techserv@stifirestop.com
Website:www.stifirestop.com

INDEX

System No. W-L-1014
ANSLUL 1479 (ASTM E814) and CANULC S115
F Ratings - 1 and 2 Hr (See Item 1)
T Rating - 1 Hr
L Rating At Ambient - Less Than 1 CFM/sq ft
L Rating At 400 F - Less Than 1 CFM/sq ft

System No. W-L-6054
ANSLUL 1479 (ASTM E814)
F Ratings - 1 & 2 Hr (See Item 1)
T Ratings - 3/4 and 1 Hr
Through Penetrants - One metallic pipe or tubing to be installed either concentrically or eccentrically within the firestop system.

System No. W-L-5262
ANSLUL 1479 (ASTM E814) and CANULC S115
F Ratings - 1 and 2 Hr (See Item 1)
T Rating - 1 Hr
L Rating At Ambient - Less Than 1 CFM/sq ft
L Rating At 400 F - Less Than 1 CFM/sq ft

System No. C-AJ-2578
ANSLUL 1479 (ASTM E814)
F Rating - 3 Hr
T Rating - 1 Hr
L Rating At Ambient - Less Than 1 CFM/sq ft
L Rating At 400 F - Less Than 1 CFM/sq ft
W Rating - Class 1 (See Item 4B)

System No. C-AJ-2282
ANSLUL 1479 (ASTM E814)
F Rating - 3 Hr
T Rating - 1 Hr
L Rating At Ambient - Less Than 1 CFM/sq ft
L Rating At 400 F - Less Than 1 CFM/sq ft
W Rating - Class 1 (See Item 4B)

System No. W-L-5262
ANSLUL 1479 (ASTM E814) and CANULC S115
F Ratings - 1 and 2 Hr (See Item 1)
T Rating - 1 Hr
L Rating At Ambient - Less Than 1 CFM/sq ft
L Rating At 400 F - Less Than 1 CFM/sq ft

System No. W-L-5262
ANSLUL 1479 (ASTM E814) and CANULC S115
F Ratings - 1 and 2 Hr (See Item 1)
T Rating - 1 Hr
L Rating At Ambient - Less Than 1 CFM/sq ft
L Rating At 400 F - Less Than 1 CFM/sq ft

System No. C-AJ-2297
ANSLUL 1479 (ASTM E814)
F Ratings - 0, 1, 2 and 3 Hr (See Item 4C)
L Rating At Ambient - Less Than 1 CFM/sq ft
L Rating At 400 F - Less Than 1 CFM/sq ft
W Rating - Class 1 (See Item 4B)

System No. C-AJ-2297
ANSLUL 1479 (ASTM E814)
F Ratings - 0, 1, 2 and 3 Hr (See Item 4C)
L Rating At Ambient - Less Than 1 CFM/sq ft
L Rating At 400 F - Less Than 1 CFM/sq ft
W Rating - Class 1 (See Item 4B)

System No. C-AJ-2297
ANSLUL 1479 (ASTM E814)
F Ratings - 0, 1, 2 and 3 Hr (See Item 4C)
L Rating At Ambient - Less Than 1 CFM/sq ft
L Rating At 400 F - Less Than 1 CFM/sq ft
W Rating - Class 1 (See Item 4B)

System No. W-L-5262
ANSLUL 1479 (ASTM E814) and CANULC S115
F Ratings - 1 and 2 Hr (See Item 1)
T Rating - 1 Hr
L Rating At Ambient - Less Than 1 CFM/sq ft
L Rating At 400 F - Less Than 1 CFM/sq ft

GENERAL NOTES:
1. Refer to section 07 84 00 of the specifications. For Quality Control requirements, refer to the Quality Control portion of the specification.
2. Details shown are typical details. If field conditions do not match requirements of typical details, approved alternate details shall be utilized. Field conditions and dimensions need to be verified for compliance with the details, including but not limited to the following:
Type and thickness of fire-rated construction. The minimum assembly shall meet or exceed the highest rating of the adjacent construction.
3. If alternate details matching the field conditions are not available, manufacturer's engineering judgment drawings are acceptable. Engineering judgments shall follow the International Firestop Council (IFC) Guidelines for Evaluating Firestop Systems Engineering Judgments.
4. References:
UL Fire Resistance Directory; Current Edition
NFPA 101 Life Safety Code
All governing local and regional building codes
5. Firestop System installation must meet requirements of ASTM E-814 (UL 1479), ASTM E1666 (UL 1479), ASTM 1966 (UL 2079), ASTM E2307, or ULC-S115 (as required) in tested assemblies that provide a fire rating equal to that of the surrounding construction.

DIVISION 4: Masonry
DIVISION 7: Thermal & Moisture Protection
DIVISION 9: Finishes
DIVISION 22: Plumbing
DIVISION 23: HVAC
DIVISION 26: Electrical
DIVISION 27: Communications
PROJECT NAME:
PROJECT LOCATION:
ARCHITECT/CONSULTANT:
ARCHITECT/CONSULTANT:
TITLE:
STI FIRESTOP SYSTEMS
Specified Technologies Inc.
210 Evans Way Somerville, NJ 08876
Toll Free: (800)992-1180
Phone: (908)526-8000
FAX (908)231-8415
E-Mail:techserv@stifiirestop.com
Website:www.stifiirestop.com

Specified Technologies Inc. 210 Evans Way Somerville, NJ 08876
Reproduced courtesy of Underwriters Laboratories, Inc.
Created or Revised: March 14, 2014
(800)992-1180 • (908)526-8000 • FAX (908)231-8415 • E-Mail:techserv@stifiirestop.com • Website:www.stifiirestop.com

Specified Technologies Inc. 210 Evans Way Somerville, NJ 08876
Reproduced courtesy of Underwriters Laboratories, Inc.
Created or Revised: January 23, 2014
(800)992-1180 • (908)526-8000 • FAX (908)231-8415 • E-Mail:techserv@stifiirestop.com • Website:www.stifiirestop.com

Specified Technologies Inc. 210 Evans Way Somerville, NJ 08876
Reproduced courtesy of Underwriters Laboratories, Inc.
Created or Revised: March 14, 2014
(800)992-1180 • (908)526-8000 • FAX (908)231-8415 • E-Mail:techserv@stifiirestop.com • Website:www.stifiirestop.com

Specified Technologies Inc. 210 Evans Way Somerville, NJ 08876
Reproduced courtesy of Underwriters Laboratories, Inc.
Created or Revised: January 23, 2014
(800)992-1180 • (908)526-8000 • FAX (908)231-8415 • E-Mail:techserv@stifiirestop.com • Website:www.stifiirestop.com

INDEX

Classified by Underwriters Laboratories, Inc. to ANSUL1479 (ASTM E814) and CANULC S115 System No. F-A-2216. Includes tables for F Rating, T Rating, L Rating, and L Rating at 400 F. Includes a cross-sectional diagram of a fire-rated wall assembly.

Classified by Underwriters Laboratories, Inc. to ASTMUL1479 (ASTM E814) and CANULC S115 System No. W-L-2241. Includes tables for R Rating, FT Rating, L Rating, and L Rating at 400 F. Includes a cross-sectional diagram of a fire-rated wall assembly.

Classified by Underwriters Laboratories, Inc. to ANSUL1479 (ASTM E814) and CANULC S115 System No. W-L-2237. Includes tables for R Rating, FT Rating, L Rating, and L Rating at 400 F. Includes a cross-sectional diagram of a fire-rated wall assembly.

Classified by Underwriters Laboratories, Inc. to ANSUL1479 (ASTM E814) and CANULC S115 System No. C-AJ-3217. Includes tables for F Rating, FT Rating, L Rating, and L Rating at 400 F. Includes a cross-sectional diagram of a fire-rated wall assembly.

Classified by Underwriters Laboratories, Inc. to ANSUL1479 (ASTM E814) and CANULC S115 System No. W-L-2257. Includes tables for F Rating, FT Rating, L Rating, and L Rating at 400 F. Includes a cross-sectional diagram of a fire-rated wall assembly.

Classified by Underwriters Laboratories, Inc. to ANSUL1479 (ASTM E814) and CANULC S115 System No. C-AJ-3260. Includes tables for F Rating, FT Rating, L Rating, and L Rating at 400 F. Includes a cross-sectional diagram of a fire-rated wall assembly.

Classified by Underwriters Laboratories, Inc. to ANSUL1479 (ASTM E814) and CANULC S115 System No. C-AJ-3262. Includes tables for F Rating, FT Rating, L Rating, and L Rating at 400 F. Includes a cross-sectional diagram of a fire-rated wall assembly.

Classified by Underwriters Laboratories, Inc. to ANSUL1479 (ASTM E814) and CANULC S115 System No. C-AJ-3317. Includes tables for F Rating, FT Rating, L Rating, and L Rating at 400 F. Includes a cross-sectional diagram of a fire-rated wall assembly.

Classified by Underwriters Laboratories, Inc. to ANSUL1479 (ASTM E814) and CANULC S115 System No. F-A-3054. Includes tables for F Rating, FT Rating, L Rating, and L Rating at 400 F. Includes a cross-sectional diagram of a fire-rated wall assembly.

Classified by Underwriters Laboratories, Inc. to ANSUL1479 (ASTM E814) and CANULC S115 System No. F-A-3054. Includes tables for F Rating, FT Rating, L Rating, and L Rating at 400 F. Includes a cross-sectional diagram of a fire-rated wall assembly.

Classified by Underwriters Laboratories, Inc. to ANSUL1479 (ASTM E814) and CANULC S115 System No. F-A-3054. Includes tables for F Rating, FT Rating, L Rating, and L Rating at 400 F. Includes a cross-sectional diagram of a fire-rated wall assembly.

Classified by Underwriters Laboratories, Inc. to ANSUL1479 (ASTM E814) and CANULC S115 System No. F-A-3054. Includes tables for F Rating, FT Rating, L Rating, and L Rating at 400 F. Includes a cross-sectional diagram of a fire-rated wall assembly.

GENERAL NOTES:

- 1. Refer to section 07 84 00 of the specifications. For Quality Control requirements, refer to the Quality Control portion of the specification.
2. Details shown are typical details. If field conditions do not match requirements of typical details, approved alternate details shall be utilized. Field conditions and dimensions need to be verified for compliance with the details, including but not limited to the following:
Type and thickness of fire-rated construction. The minimum assembly rating of the firestop assembly shall meet or exceed the highest rating of the adjacent construction.
3. If alternate details matching the field conditions are not available, manufacturer's engineering judgment drawings are acceptable. Engineering Judgments shall follow the International Firestop Council (IFC) Guidelines for Evaluating Firestop Systems Engineering Judgments.
4. References:
UL Fire Resistance Directory; Current Edition
NFPA 101 Life Safety Code
All governing local and regional building codes
5. Firestop System installation must meet requirements of ASTM E-814 (UL 1479), ASTM E1966 (UL 1479), ASTM 1966 (UL 2079), ASTM E2307, or ULC-S115 (as required) in tested assemblies that provide a fire rating equal to that of the surrounding construction.

- DIVISION 4: Masonry
DIVISION 7: Thermal & Moisture Protection
DIVISION 9: Finishes
DIVISION 22: Plumbing
DIVISION 23: HVAC
DIVISION 26: Electrical
DIVISION 27: Communications

PROJECT NAME:

PROJECT_NAME:

PROJECT LOCATION:

PROJECT_LOCATION:

ARCHITECT/CONSULTANT:

ARCHITECT/CONSULTANT:

TITLE:

STI FIRESTOP SYSTEMS

Specified Technologies Inc.
210 Evans Way Somerville, NJ 08876

Toll Free: (800)992-1180
Phone: (908)526-8000
FAX (908)231-8415
E-Mail:techserv@stifirestop.com
Website:www.stifirestop.com


Specified Technologies Inc. 210 Evans Way Somerville, NJ 08876. Includes STI logo and UL certification marks.

Specified Technologies Inc. 210 Evans Way Somerville, NJ 08876. Includes STI logo and UL certification marks.

Specified Technologies Inc. 210 Evans Way Somerville, NJ 08876. Includes STI logo and UL certification marks.

Specified Technologies Inc. 210 Evans Way Somerville, NJ 08876. Includes STI logo and UL certification marks.

Table for System No. F.A-3064. Columns: ANSUL1479 (ASTM E814), CANULC S115. Rows: F Rating - 2 HR, T Ratings - 1:14 and 2 HR (See Item 5), L Rating at Ambient - 2 to 14 CFM/Device (See Item 4C), L Rating at 400°F - 2 to 14 CFM/Device (See Item 4C).




- 1. Floor Assembly - Min 4-1/2 in. (114 mm) thick reinforced lightweight or normal weight (100-150 pcf or 1600-2400 kg/m3) concrete floor. Floor may also be constructed of any UL Classified Concrete Blocks. Max area of opening is 4-1/2 in. (114 mm) ...

Table for System No. 210 Evans Way Somerville, NJ 08876. Columns: UL, E-Label, R-Label, P-Label, F.A.3064 PAGE 1 OF 1.

Table for System No. W.J-3240. Columns: ANSUL1479 (ASTM E814), CANULC S115. Rows: F Rating - 2 HR, T Ratings - 0 and 1/2 Hr (See Item 2), L Rating at Ambient - Less than 15 to 10.7 CFM/Device (See Item 4C), L Rating at 400°F - Less than 15 to 10.7 CFM/Device (See Item 4C).


Table for System No. W.J-3240. Columns: ANSUL1479 (ASTM E814), CANULC S115. Rows: F Rating - 2 HR, T Ratings - 0 and 1/2 Hr (See Item 2), L Rating at Ambient - Less than 15 to 10.7 CFM/Device (See Item 4C), L Rating at 400°F - Less than 15 to 10.7 CFM/Device (See Item 4C).



- 1. Wall Assembly - Min 5 in. (127 mm) thick reinforced lightweight or normal weight (100-150 pcf or 1600-2400 kg/m3) concrete. Wall assembly may also be constructed of any UL Classified Concrete Blocks. Max diam of opening is 4 in. (102 mm) ...

Table for System No. 210 Evans Way Somerville, NJ 08876. Columns: UL, E-Label, R-Label, P-Label, W.J-3240 PAGE 1 OF 1.


Table for System No. C.A-J-6008. Columns: ANSUL1479 (ASTM E814), CANULC S115. Rows: F Rating - 3 Hr, T Ratings - 0 and 1/2 Hr (See Item 2), L Rating at Ambient - Less than 1.5 CFM/ft2, L Rating at 400°F - Less than 1 CFM/ft2.



- 1. Floor or Wall Assembly - Min 4-1/2 in. (114 mm) thick reinforced lightweight or normal weight (100-150 pcf or 1600-2400 kg/m3) concrete. Wall may also be constructed of any UL Classified Concrete Blocks. Opening shall be 2 in. (51 mm) 4 in. (102 mm) greater than length and width dimensions of burway (Item 2). ...

Table for System No. 210 Evans Way Somerville, NJ 08876. Columns: UL, E-Label, R-Label, P-Label, C.A-J-6008 PAGE 1 OF 1.


Table for System No. W.L-3435. Columns: ANSUL1479 (ASTM E814), CANULC S115. Rows: F Ratings - 1 and 2 Hr (See Item 1), T Ratings - 0 and 1/2 Hr (See Item 2), L Rating at Ambient - Less than 1 to 10.7 CFM/Device (See Item 4C), L Rating at 400°F - Less than 1 to 10.7 CFM/Device (See Item 4C).



- 1. Wall Assembly - The 1 or 2 hr fire rated gypsum board/wall assembly shall be constructed of the materials and in the manner specified in the individual L300, V300, L400, V400, W400 Series Wall and Partition Designs in the UL Fire Resistance Directory and shall include the following construction features: ...

Table for System No. 210 Evans Way Somerville, NJ 08876. Columns: UL, E-Label, R-Label, P-Label, W.L-3435 PAGE 1 OF 1.


Table for System No. W.L-3435. Columns: ANSUL1479 (ASTM E814), CANULC S115. Rows: F Ratings - 1 and 2 Hr (See Item 1), T Ratings - 0 and 1/2 Hr (See Item 2), L Rating at Ambient - Less than 1 to 10.7 CFM/Device (See Item 4C), L Rating at 400°F - Less than 1 to 10.7 CFM/Device (See Item 4C).



- 2. Steel Sleeve (Optional) - Nom 1-1/2 in. (38 mm), 2 in. (51 mm), 3 in. (76 mm) or 4 in. (102 mm) diam steel electrical metallic tubing (EMT), steel conduit, Schedule 5 (or heavier) steel pipe sleeve or min 0.016 in. thick (0.41 mm, No. 28 gaw) galv sheet steel sleeve installed flush with wall surfaces. The annular space between the steel sleeve and periphery of opening shall be min 0 in. (continuous point contact) to max 1 in. (25 mm). Steel sleeve shall be installed in continuous point contact only. ...

Table for System No. 210 Evans Way Somerville, NJ 08876. Columns: UL, E-Label, R-Label, P-Label, W.L-3435 PAGE 1 OF 1.


Table for System No. W.L-3435. Columns: ANSUL1479 (ASTM E814), CANULC S115. Rows: F Ratings - 1 and 2 Hr (See Item 1), T Ratings - 0 and 1/2 Hr (See Item 2), L Rating at Ambient - Less than 1 to 10.7 CFM/Device (See Item 4C), L Rating at 400°F - Less than 1 to 10.7 CFM/Device (See Item 4C).



- 3. Cables - Cables may represent a min 50 to max 100 percent visual fill within the loading area for the sleeve, a nominal 2 in. (51 mm) opening or a nominal 4 in. (102 mm) opening. Cables to be rigidly supported on both sides of the wall assembly. Any combination of the following types and sizes of cables may be used: ...

Table for System No. 210 Evans Way Somerville, NJ 08876. Columns: UL, E-Label, R-Label, P-Label, W.L-3435 PAGE 1 OF 1.


Table for System No. C.A-J-6008. Columns: ANSUL1479 (ASTM E814), CANULC S115. Rows: F Rating - 3 Hr, T Ratings - 0 and 1/2 Hr (See Item 2), L Rating at Ambient - Less than 1.5 CFM/ft2, L Rating at 400°F - Less than 1 CFM/ft2.



- 1. Floor or Wall Assembly - Min 4-1/2 in. (114 mm) thick reinforced lightweight or normal weight (100-150 pcf or 1600-2400 kg/m3) concrete. Wall may also be constructed of any UL Classified Concrete Blocks. Opening shall be 2 in. (51 mm) 4 in. (102 mm) greater than length and width dimensions of burway (Item 2). ...

Table for System No. 210 Evans Way Somerville, NJ 08876. Columns: UL, E-Label, R-Label, P-Label, C.A-J-6008 PAGE 1 OF 1.


Table for System No. C.BK-6001. Columns: ANSUL1479 (ASTM E814), CANULC S115. Rows: F Rating - 3 Hr, T Ratings - 2:14 Hr, L Rating at Ambient - 5.5 CFM/ft2, L Rating at 400°F - 5.5 CFM/ft2.



- 1. Floor or Wall Assembly - Min 9 in. (229 mm) thick reinforced lightweight or normal weight (100-150 pcf or 1600-2400 kg/m3) concrete. Wall may also be constructed of any UL Classified Concrete Blocks. Max area of opening is 312 sq in. (2013 cm2) with max dimension of 26.24 in. (756 mm). ...

Table for System No. 210 Evans Way Somerville, NJ 08876. Columns: UL, E-Label, R-Label, P-Label, C.BK-6001 PAGE 1 OF 1.

Table for System No. C.BK-6001. Columns: ANSUL1479 (ASTM E814), CANULC S115. Rows: F Rating - 3 Hr, T Ratings - 2:14 Hr, L Rating at Ambient - 5.5 CFM/ft2, L Rating at 400°F - 5.5 CFM/ft2.



- 3. Firestop System - The firestop system shall consist of the following: 1. Fill, Void or Cavity Material - Wrap - Nom 4 in. (101 mm) flexible sheet material. A min of two layers of wrap material are required. In floor the first layer of wrap material shall be positioned flush with the bottom plane of the floor and project a min 25 in. (635 mm) above the top surface of the floor. The second layer of wrap material shall be positioned flush with the top surface of the floor and project a min 12 in. (305 mm) above the top surface of the floor. In walls the first layer of wrap material shall be continuous within the wall and project a min 25 in. (635 mm) beyond each surface of the wall and the second layer of wrap material shall project a min 12 in. (305 mm) beyond each surface of the wall. Individual layers of wrap material shall be installed with each layer of wrap material installed by cutting and wrapping around the burway and half such that a min 1-1/2 in. (38 mm) overlap is present along the longitudinal seams and with adjacent lengths of wrap material in each layer to be installed with tightly-butted seams. Successive layers of wrap material installed in same manner with butted and seams offset min 1-1/2 in. (38 mm) from butted and seams of preceding layer. Wrap material should be maintained contact with all sides of burway. Cut edges and seams of wrap material covered with one layer of aluminum foil tape. Wrap material layers secured in place with steel tie wire (Item 3B) on outermost layer. ...

Table for System No. 210 Evans Way Somerville, NJ 08876. Columns: UL, E-Label, R-Label, P-Label, C.BK-6001 PAGE 1 OF 1.

GENERAL NOTES:

- 1. Refer to section 07 84 00 of the specifications. For Quality Control requirements, refer to the Quality Control portion of the specification.
2. Details shown are typical details. If field conditions do not match requirements of typical details, approved alternate details shall be utilized. Field conditions and dimensions need to be verified for compliance with the details, including but not limited to the following:
- Type and thickness of fire-rated construction. The minimum assembly rating of the firestop assembly shall meet or exceed the highest rating of the adjacent construction.
3. If alternate details matching the field conditions are acceptable, manufacturer's engineering judgment drawings are acceptable. Engineering Judgments shall follow the International Firestop Council (IFC) Guidelines for Evaluating Firestop Systems Engineering Judgments.
4. References:
- UL Fire Resistance Directory; Current Edition
- NFPA 101 Life Safety Code
- All governing local and regional building codes
5. Firestop System installation must meet requirements of ASTM E-814 (UL 1479), ASTM E1966 (UL 1479), ASTM 1966 (UL 2079), ASTM E2307, or ULC-S115 (as required) in tested assemblies that provide a fire rating equal to that of the surrounding construction.

Form for project information including: DIVISION 4: Masonry, DIVISION 7: Thermal & Moisture Protection, DIVISION 9: Finishes, DIVISION 22: Plumbing, DIVISION 23: HVAC, DIVISION 26: Electrical, DIVISION 27: Communications, PROJECT NAME, PROJECT LOCATION, ARCHITECT/CONSULTANT, TITLE: STI FIRESTOP SYSTEMS, Specified Technologies Inc., 210 Evans Way Somerville, NJ 08876, Toll Free: (800)992-1180, Phone: (908)526-8000, FAX (908)231-8415, E-Mail: techserv@stifiestop.com, Website: www.stifiestop.com

System No. WL-7066. Classified by Underwriters Laboratories, Inc. to ANSIUL 1479 (ASTM E814) and CANULC S115. Includes tables for ratings and diagrams for wall assembly and section A-A.

System No. WL-7090. Classified by Underwriters Laboratories, Inc. to ASTMUL 1479 (ASTM E814). Includes tables for ratings and diagrams for wall assembly and section A-A.

System No. WL-7200. Classified by Underwriters Laboratories, Inc. to ANSIUL 1479 (ASTM E814) and CANULC S115. Includes tables for ratings and diagrams for wall assembly and section A-A.

System No. WL-7252. Classified by Underwriters Laboratories, Inc. to ANSIUL 1479 (ASTM E814) and CANULC S115. Includes tables for ratings and diagrams for wall assembly and section A-A.

System No. WL-7238. Classified by Underwriters Laboratories, Inc. to ANSIUL 1479 (ASTM E814) and CANULC S115. Includes tables for ratings and diagrams for wall assembly and section A-A.

System No. WL-7238. Classified by Underwriters Laboratories, Inc. to ANSIUL 1479 (ASTM E814) and CANULC S115. Includes tables for ratings and diagrams for wall assembly and section A-A.

System No. WL-7253. Classified by Underwriters Laboratories, Inc. to ANSIUL 1479 (ASTM E814) and CANULC S115. Includes tables for ratings and diagrams for wall assembly and section A-A.

System No. WL-7253. Classified by Underwriters Laboratories, Inc. to ANSIUL 1479 (ASTM E814) and CANULC S115. Includes tables for ratings and diagrams for wall assembly and section A-A.

System No. WL-7253. Classified by Underwriters Laboratories, Inc. to ANSIUL 1479 (ASTM E814) and CANULC S115. Includes tables for ratings and diagrams for wall assembly and section A-A.

System No. WL-7253. Classified by Underwriters Laboratories, Inc. to ANSIUL 1479 (ASTM E814) and CANULC S115. Includes tables for ratings and diagrams for wall assembly and section A-A.

System No. WL-7253. Classified by Underwriters Laboratories, Inc. to ANSIUL 1479 (ASTM E814) and CANULC S115. Includes tables for ratings and diagrams for wall assembly and section A-A.

System No. WL-7253. Classified by Underwriters Laboratories, Inc. to ANSIUL 1479 (ASTM E814) and CANULC S115. Includes tables for ratings and diagrams for wall assembly and section A-A.

GENERAL NOTES:

- 1. Refer to section 07 84 00 of the specifications. For Quality Control requirements, refer to the Quality Control portion of the specification.
2. Details shown are typical details. If field conditions do not match requirements of typical details, approved alternate details shall be utilized. Field conditions and dimensions need to be verified for compliance with the details, including but not limited to the following:
- Type and thickness of fire-rated construction. The minimum assembly rating of the firestop assembly shall meet or exceed the highest rating of the adjacent construction.
3. If alternate details matching the field conditions are not available, manufacturer's engineering judgment drawings are acceptable. Engineering Judgments shall follow the International Firestop Council (IFC) Guidelines for Evaluating Firestop Systems Engineering Judgments.

- 4. References:
- UL Fire Resistance Directory; Current Edition
- NFPA 101 Life Safety Code
- All governing local and regional building codes
5. Firestop System installation must meet requirements of ASTM E-814 (UL 1479), ASTM E1966 (UL 1479), ASTM 1966 (UL 2079), ASTM E2307, or ULC-S115 (as required) in tested assemblies that provide a fire rating equal to that of the surrounding construction.

- DIVISION 4: Masonry
DIVISION 7: Thermal & Moisture Protection
DIVISION 9: Finishes
DIVISION 22: Plumbing
DIVISION 23: HVAC
DIVISION 26: Electrical
DIVISION 27: Communications

PROJECT NAME: PROJECT_NAME:
PROJECT LOCATION: PROJECT_LOCATION:
ARCHITECT/CONSULTANT: ARCHITECT/CONSULTANT:

TITLE: STI FIRESTOP SYSTEMS
Specified Technologies Inc.
210 Evans Way Somerville, NJ 08876

Toll Free: (800)992-1180
Phone: (908)526-8000
FAX (908)231-8415
E-Mail:techserv@stifirestop.com
Website:www.stifirestop.com



INDEX

System No. WL-8026. Classified by Underwriters Laboratories, Inc. to ANSUL 1479 (ASTM E814) and CANULC S115. Includes tables for ratings and fire resistance details.

System No. WL-8026. Includes technical drawings showing cross-sections of fire-rated walls and details for various components like pipes and cables.

System No. WL-8026. Lists technical specifications for fire-rated walls, including material types, thicknesses, and testing procedures.

System No. WL-8026. Provides detailed information on fire-rated wall assemblies, including material specifications and performance requirements.

System No. WL-8050. Classified by Underwriters Laboratories, Inc. to ANSUL 1479 (ASTM E814) and CANULC S115. Includes tables for ratings and fire resistance details.

System No. WL-8050. Includes technical drawings showing cross-sections of fire-rated walls and details for various components like pipes and cables.

System No. WL-8050. Lists technical specifications for fire-rated walls, including material types, thicknesses, and testing procedures.

System No. C-AJ-1217. Classified by Underwriters Laboratories, Inc. to ASTM A1479 (ASTM E814). Includes tables for ratings and fire resistance details.

System No. C-AJ-1217. Includes technical drawings showing cross-sections of fire-rated walls and details for various components like pipes and cables.

System No. C-AJ-1217. Lists technical specifications for fire-rated walls, including material types, thicknesses, and testing procedures.

System No. C-AJ-1217. Provides detailed information on fire-rated wall assemblies, including material specifications and performance requirements.

System No. C-AJ-1217. Includes technical drawings showing cross-sections of fire-rated walls and details for various components like pipes and cables.

GENERAL NOTES:

- 1. Refer to section 07 84 00 of the specifications. For Quality Control requirements, refer to the Quality Control portion of the specification.
2. Details shown are typical details. If field conditions do not match requirements of typical details, approved alternate details shall be utilized.
3. If alternate details matching the field conditions are not available, manufacturer's engineering judgment drawings are acceptable.
4. References: UL Fire Resistance Directory; Current Edition; NFPA 101 Life Safety Code; All governing local and regional building codes.
5. Firestop System installation must meet requirements of ASTM E-814 (UL 1479), ASTM E1966 (UL 1479), ASTM 1966 (UL 2079), ASTM E2307, or ULC-S115 (as required) in tested assemblies that provide a fire rating equal to that of the surrounding construction.

DIVISION 4: Masonry
DIVISION 7: Thermal & Moisture Protection
DIVISION 9: Finishes
DIVISION 22: Plumbing
DIVISION 23: HVAC
DIVISION 26: Electrical
DIVISION 27: Communications

PROJECT NAME: PROJECT_NAME

PROJECT LOCATION: PROJECT_LOCATION

ARCHITECT/CONSULTANT: ARCHITECT/CONSULTANT

TITLE: STI FIRESTOP SYSTEMS
Specified Technologies Inc.
210 Evans Way Somerville, NJ 08876

Toll Free: (800)992-1180
Phone: (908)526-8000
FAX (908)231-8415
E-Mail:techserv@stifirestop.com
Website:www.stifirestop.com



Classified by Underwriters Laboratories, Inc. to UL 1489

System No. FP-3
*Fire Resistance Rating - 2 Hr

Section A-A

- Fuel Pipe Assembly** - Nom 1 in. (25 mm) Max 4 in. (102 mm) diam Schedule 40 (or heavier) steel pipe. All fittings shall be welded.
- Pipe Supports** - (Not Shown) - Pipe shall be supported by steel pipe hangers in conjunction with min 3/8 in. (10 mm) diameter threaded steel rod. Refer to the manufacturer's installation instructions for additional details.
- Fire-resistant Pipe-protection System** - The fire-resistant pipe-protection system consists of a wrap, foil tape, steel tie wire and caulk. The system shall be installed in accordance with the detailed installation instruction manual supplied by the manufacturer of the Fire-resistant Pipe-protection Materials*. The details of the fire-resistant pipe-protection system are summarized below.
 - Fire-resistant Pipe-protection Materials* - Mat** - Nom 0.5 in. (12.7 mm) flexible sheet material. A min of five layers of wrap are required for pipe smaller than 4 in (102 mm). For 4 in (102 mm) pipe, 4 layers are required. A minimum of two layers of wrap are required for the pipe support system per manufacturer's instructions. There are three wrapping methods for pipe as follows:

Config A: - Install wrap by cutting to size and wrapping around the fuel pipe assembly (Item 1) and itself such that a min 2 in. (51 mm) overlap is present along the longitudinal seam. Adjacent lengths of wrap in each layer to be installed with tightly butted end seams. Install a 1/8 depth of caulk (Item 3E) at the butted seam. Install foil tape (Item 3B) along the final longitudinal edge of the overlap and over each seam of the outer layer between adjacent sections of wrap.

Config B: - Install wrap by cutting to size and wrapping around the fuel pipe assembly (Item 1) and itself such that a min 2 in. (51 mm) overlap is present along the longitudinal seam. Adjacent lengths of wrap in each layer to be installed with tightly butted end seams. Successive layers of wrap installed in same manner with butted end seams offset from 0 in (0 mm) to 2 in. (51 mm) from butted end seams of preceding layer. Install a 1/8 depth of caulk (Item 3E) at the butted seam. All seams in each layer of wrap to be sealed with foil tape (Item 3B).

Reproduced courtesy of Underwriters Laboratories, Inc.
Created or Revised: January 08, 2020

Specified Technologies Inc. 210 Evans Way Somerville, NJ 08876
 (800)992-1180 • (908)526-8000 • FAX (908)231-8415 • E-Mail:techserv@stifirestop.com • Website:www.stifirestop.com

STI UL FP-3 PAGE 1 OF 2

Classified by Underwriters Laboratories, Inc. to UL 1489

System No. FP-4
Fire Resistance Rating - 2 Hr

Section A-A

Config C: - Install wrap by cutting to size and wrapping around the fuel pipe assembly (Item 1) and itself such that a single piece of wrap completes all required layers and overlaps past the initial edge 2 in. (51 mm) for each layer that is required by the system. Adjacent lengths of wrap in each layer to be installed with tightly butted end seams. Install a 1/8 depth of caulk (Item 3E) at the butted seam. Install foil tape (Item 3B) along the final longitudinal edge of the overlap and over each seam of the outer layer between adjacent sections of wrap.

SPECIFIED TECHNOLOGIES INC - E-Wrap Endothermic Wrap

I. Foil Tape - (Not Shown) - Nom 3 in. (76 mm) wide min 3 mil (0.08 mm) thick pressure-sensitive aluminum foil tape, supplied in rolls. Used to secure seams of wrap (Item 3A).

C. Steel Tie-Wire - Nominal 18 ga. or heavier, steel wire ties installed over the outermost layer of wrap 1 in. (25 mm) from each seam between adjacent sections of wrap and 6 in. (152 mm) OC between seams.

D. Fill, Void or Cavity Materials* - Caulk - Any joint between the adjacent layers of wrap that exceed 1/8 in. (3.2 mm) in width shall be filled with caulk to the full depth of the joint. For configurations 2 and 3 of Item 3A, install a 1/8 in (3.2 mm) depth of caulk between the abutting edges of each layer between adjacent sections of wrap.

SPECIFIED TECHNOLOGIES INC - SpecSeal Series SSS Sealant or SpecSeal Series LCI Sealant

* Indicates such products shall bear the UL or cUL Certification Mark for jurisdictions employing the UL or cUL Certification (such as Canada), respectively.

Reproduced courtesy of Underwriters Laboratories, Inc.
Created or Revised: January 08, 2020

Specified Technologies Inc. 210 Evans Way Somerville, NJ 08876
 (800)992-1180 • (908)526-8000 • FAX (908)231-8415 • E-Mail:techserv@stifirestop.com • Website:www.stifirestop.com

STI UL FP-3 PAGE 2 OF 2

Classified by Underwriters Laboratories, Inc. to UL 1489

System No. FP-4
Fire Resistance Rating - 2 Hr

Section A-A

- Fuel Pipe Assembly** - One or more nom 1 in. (25 mm) diam Max 2 in. (51 mm) Schedule 40 (or heavier) steel pipe with continuously welded fittings installed symmetrically within the outer containment pipe (Item 2) utilizing steel pipe spacers.
- Outer Containment Pipe** - Nom 3 in. (76 mm) Max 4 in. (102 mm) diam Schedule 40 (or heavier) steel pipe with continuously welded fittings. Outer containment pipe is sized a minimum 2 sizes larger than the fuel pipe assembly (Item 1).
- Pipe Supports** - (Not Shown) - Outer containment pipe shall be supported by steel pipe hangers in conjunction with min 3/8 in. (10 mm) diameter threaded steel rod. A minimum of two layers of wrap are required for the pipe support system per manufacturer's instructions. Refer to the manufacturer's installation instructions for additional details.
- Fire-resistant Pipe-protection System** - The fire-resistant pipe-protection system consists of a wrap, foil tape, steel tie wire and caulk. The system shall be installed in accordance with the detailed installation instruction manual supplied by the manufacturer of the Fire-resistant Pipe-protection Materials*. The details of the fire-resistant pipe-protection system are summarized below.
 - Fire-resistant Pipe-protection Materials* - Mat** - Nom 0.5 in. (12.7 mm) flexible sheet material. For outer containment pipe less than nom 4 in diam, min of five layers of wrap are required. For outer containment pipe of 4 in. diam, min of four layers of wrap are required. A minimum of two layers of wrap are required for the pipe support system per manufacturer's instructions. There are three wrapping methods for pipe as follows:

Config A: - Install wrap by cutting to size and wrapping around the containment pipe (Item 2) and itself such that a min 2 in. (51 mm) overlap is present along the longitudinal seam. Adjacent lengths of wrap in each layer to be installed with tightly butted end seams. Successive layers of wrap installed in same manner with butted end seams offset min 2 in. (51 mm) from butted end seams of preceding layer. All seams in each layer of wrap to be sealed with foil tape (Item 4B).

Config B: - Install wrap by cutting to size and wrapping around the containment pipe (Item 2) and itself such that a min 2 in. (51 mm) overlap is present along the longitudinal seam. Adjacent lengths of wrap in each layer to be installed with tightly butted end seams. Successive layers of wrap installed in same manner with butted end seams offset from 0 in (0 mm) to 2 in. (51 mm) from butted end seams of preceding layer. Install a 1/8 depth of caulk (Item 4E) at the butted seam. All seams in each layer of wrap to be sealed with foil tape (Item 4B).

Reproduced courtesy of Underwriters Laboratories, Inc.
Created or Revised: January 08, 2020

Specified Technologies Inc. 210 Evans Way Somerville, NJ 08876
 (800)992-1180 • (908)526-8000 • FAX (908)231-8415 • E-Mail:techserv@stifirestop.com • Website:www.stifirestop.com

STI UL FP-4 PAGE 1 OF 2

Classified by Underwriters Laboratories, Inc. to UL 1489

System No. FP-4
Fire Resistance Rating - 2 Hr

Section A-A

Config C: - Install wrap by cutting to size and wrapping around the containment pipe (Item 2) and itself such that a single piece of wrap completes all required layers and overlaps past the initial edge 2 in. (51 mm) for each layer that is required by the system. Adjacent lengths of wrap in each layer to be installed with tightly butted end seams. Install a 1/8 depth of caulk (Item 4E) at the butted seam. Install foil tape (Item 4B) along the final longitudinal edge of the overlap and over each seam of the outer layer between adjacent sections of wrap.

SPECIFIED TECHNOLOGIES INC - E-Wrap Endothermic Wrap

I. Foil Tape - (Not Shown) - Nom 3 in. (76 mm) wide min 3 mil (0.08 mm) thick pressure-sensitive aluminum foil tape, supplied in rolls. Used to secure seams of wrap (Item 4A).

C. Steel Tie-Wire - Nominal 18 ga. or heavier, steel wire ties installed over the outermost layer of wrap 1 in. (25 mm) from each seam between adjacent sections of wrap and 6 in. (152 mm) OC between seams.

D. Fill, Void or Cavity Materials* - Caulk - Any joint between the adjacent layers of wrap that exceed 1/8 in. (3.2 mm) in width shall be filled with caulk to the full depth of the joint. For Methods 2 and 3 of Item 4A, install a 1/8 in (3.2 mm) depth of caulk between the abutting edges of each layer between adjacent sections of wrap.

SPECIFIED TECHNOLOGIES INC - SpecSeal Series SSS Sealant or SpecSeal Series LCI Sealant

* Indicates such products shall bear the UL or cUL Certification Mark for jurisdictions employing the UL or cUL Certification (such as Canada), respectively.

Reproduced courtesy of Underwriters Laboratories, Inc.
Created or Revised: January 08, 2020

Specified Technologies Inc. 210 Evans Way Somerville, NJ 08876
 (800)992-1180 • (908)526-8000 • FAX (908)231-8415 • E-Mail:techserv@stifirestop.com • Website:www.stifirestop.com

STI UL FP-4 PAGE 2 OF 2

Classified by Underwriters Laboratories, Inc. to UL 1724

System No. C-AJ-5437

ANSIUL1479 (ASTM E814)	ANSIUL1479 (ASTM E814)
F Rating - 2 Hr	F Rating - 2 Hr
T Rating - 2 Hr	FT Rating - 2 Hr
	FH Rating - 2 Hr
	FTM Rating - 2 Hr

- Floor or Wall Assembly** - Min 4-1/2 in. (114 mm) thick reinforced lightweight or normal weight (100-150 pcf or 1600-2400 kg/m³) concrete floor or min 5 in. (127 mm) thick reinforced lightweight or normal weight (100-150 pcf or 1600-2400 kg/m³) concrete wall. Floor may also be constructed of any min 6 in. (152 mm) thick UL Classified hollow-core Precast Concrete Units*. Wall may also be constructed of any UL Classified Concrete Blocks*. Max diam of opening is 10 in. (254 mm). Max diam of opening in floor constructed of hollow-core precast concrete units is 7 in. (178 mm). See Concrete Blocks (CACT) and Precast Concrete Units (CTU) categories in the Fire Resistance Directory for names of manufacturers.
- Through Penetrants** - One metallic pipe to be installed either concentrically or eccentrically within the firestop system. Pipe to be rigidly supported on both sides of floor or wall assembly. The following types and sizes of metallic pipes may be used:
 - Steel Pipe** - Nom 4 in. (102 mm) diam (or smaller) Schedule 40 (or heavier) steel pipe.
 - Iron Pipe** - Nom 4 in. (102 mm) diam (or smaller) cast or ductile iron pipe.
- Through Penetrants** - (Not Shown) As an option to 2, a pipe system may consist of an inner pipe and an outer containment pipe of the same material acceptable in Item 2, as long as the outer containment pipe meets the criteria of Item 2.
- Pipe Coverings - Fire-resistant Pipe-protection Materials* - Wrap** - Nom 0.5 in. (12.7 mm) flexible sheet material. A min of four layers of wrap are required. All seams in each layer of wrap to be sealed with foil tape. Wrap layers secured in place with 18 ga. steel tie wire on outermost layer.

SPECIFIED TECHNOLOGIES INC - E-Wrap Endothermic Wrap

Reproduced courtesy of Underwriters Laboratories, Inc.
Created or Revised: January 08, 2020

Specified Technologies Inc. 210 Evans Way Somerville, NJ 08876
 (800)992-1180 • (908)526-8000 • FAX (908)231-8415 • E-Mail:techserv@stifirestop.com • Website:www.stifirestop.com

STI UL US C-AJ-5437 PAGE 1 OF 2

Classified by Underwriters Laboratories, Inc. to UL 1724

System No. C-AJ-5437

- Firestop System** - The firestop system shall consist of the following:
 - Packing Material** - Min 4 in. (102 mm) thickness of min 4 pcf (64 kg/m³) mineral wool batt insulation compressed and firmly packed within annular space. Packing material to be recessed from top surface of floor or from both surfaces of wall to accommodate the required thickness of fill material (Item 4B).
 - Fill, Void or Cavity Material* - Sealant** - Min 1/2 in. (13 mm) thickness of fill material applied within the annulus, flush with top surface of floor or with both surfaces of wall. When min annular space is less than 1/2 in. (13 mm), fill material to be installed to min 1 in. (25 mm) thickness.

SPECIFIED TECHNOLOGIES INC - SpecSeal MP Putty, SpecSeal Series SSS Sealant, or SpecSeal LCI Sealant

* Indicates such products shall bear the UL or cUL Certification Mark for jurisdictions employing the UL or cUL Certification (such as Canada), respectively.

Reproduced courtesy of Underwriters Laboratories, Inc.
Created or Revised: January 08, 2020

Specified Technologies Inc. 210 Evans Way Somerville, NJ 08876
 (800)992-1180 • (908)526-8000 • FAX (908)231-8415 • E-Mail:techserv@stifirestop.com • Website:www.stifirestop.com

STI UL US C-AJ-5437 PAGE 2 OF 2

GENERAL NOTES:

- Refer to section 07 84 00 of the specifications. For Quality Control requirements, refer to the Quality Control portion of the specification.
- Details shown are typical details. If field conditions do not match requirements of typical details, approved alternate details shall be utilized. Field conditions and dimensions need to be verified for compliance with the details, including but not limited to the following:
 - Type and thickness of fire-rated construction. The minimum assembly rating of the firestop assembly shall meet or exceed the highest rating of the adjacent construction.
- If alternate details matching the field conditions are not available, manufacturer's engineering judgment drawings are acceptable. Engineering Judgments shall follow the International Firestop Council (IFC) Guidelines for Evaluating Firestop Systems Engineering Judgments.
- References:
 - UL Fire Resistance Directory; Current Edition
 - NFPA 101 Life Safety Code
 - All governing local and regional building codes
- Firestop System installation must meet requirements of ASTM E-814 (UL 1479), ASTM E1966 (UL 1479), ASTM 1966 (UL 2079), ASTM E2307, or ULC-S115 (as required) in tested assemblies that provide a fire rating equal to that of the surrounding construction.

- DIVISION 4: Masonry
 DIVISION 7: Thermal & Moisture Protection
 DIVISION 9: Finishes
 DIVISION 22: Plumbing
 DIVISION 23: HVAC
 DIVISION 26: Electrical
 DIVISION 27: Communications

PROJECT NAME:
PROJECT_NAME:

PROJECT LOCATION:
PROJECT_LOCATION:

ARCHITECT/CONSULTANT:
ARCHITECT/CONSULTANT:

TITLE:
STI FIRESTOP SYSTEMS

Specified Technologies Inc.
210 Evans Way Somerville, NJ 08876

Toll Free: (800)992-1180
 Phone: (908)526-8000
 FAX (908)231-8415
 E-Mail:techserv@stifirestop.com
 Website:www.stifirestop.com

