



**CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION  
OFFICE OF THE STATE FIRE MARSHAL  
FIRE ENGINEERING & INVESTIGATIONS DIVISION  
BUILDING MATERIALS LISTING PROGRAM**

**LISTING SERVICE**

<b>LISTING No.:</b>	4485-1332:0114
<b>CATEGORY:</b>	4485 - OPENING PROTECTION (FIRESTOPPING)
<b>LISTEE:</b>	SPECIFIED TECHNOLOGIES 210 Evans Way, Somerville, NJ, 08876 Contact: Vail, David (908) 526-8000 (908) 231-8415 Email: dvail@stifirestop.com
<b>DESIGN:</b>	SpecSeal® FyreFlange™ Firestop Angle, Corner Clip and Splice Angle. Refer to listee's product data sheet and UL Fire Resistance Directory for additional detailed product description and operational considerations.
<b>RATING:</b>	
<b>INSTALLATION:</b>	In accordance with listee's printed installation instructions, UL Fire Resistance Directory, applicable codes and ordinances and in a manner acceptable to the authority having jurisdiction.
<b>MARKING:</b>	Listee's name, type identification and UL label.
<b>APPROVAL:</b>	Listed as ½-hour, 1-hour, 2-hour fire-rated firestop systems for through-penetration firestop systems when installed in accordance with the UL Fire Resistance Directory. Refer to UL Fire Resistance Directory for detailed information for the specific assembly. Through-Penetration Firestop Systems: W-J-7092, and W-L-7164.
<b>NOTES:</b>	

03-13-12 gt



This listing is based upon technical data submitted by the applicant. OSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

**Date Issued: 03/28/2024**

**Listing Expires: 06/30/2025**

Authorized By: **David Castillo**, Program Coordinator  
Fire Engineering & Investigations Division