



December 14, 2023

Testing was performed in accordance with:

ASCE 19-96, 3.2.2., which requires fitting to develop an ultimate strength of at least 110% of the specified nominal cable strength.

Lot No.: 334828 007

Date: 12/5/23

| BRACE-GRIP® Dead-End CAT. NO. | Strand Size (in.) | Strand RBS (lbs.) | Maximum Load (lbs.) | % of RBS | Failure Mode at Maximum Load |
|-------------------------------------|----------------------|----------------------|------------------------|-------------|---|
| BRG-1587 | 5/8" EHS G.S. | 42,400 | 47,520 | 112 | Strand broke mid span. No slip from either dead-end. |
| | | | 47,520 | 112 | Strand broke mid span. No slip from either dead-end. |
| | | AVERAGE | 47,520 | 112 | |

Regards,

Scott L. Sanderson

Senior Quality Engineer

RMB

cc: File 94, M. Miller

PLP.COM