



November 8, 2023

Testing was performed in accordance with:

ASCE 19-96, 3.2.2., which requires fitting to develop an ultimate strength of at least 110% of the specified nominal cable strength.

Lot No.: 617506

Date: 11/2/23

| BRACE-GRIP® Dead-End CAT. NO. | Strand Size (in.) | Strand RBS (lbs.) | Maximum Load (lbs.) | % of RBS | Failure Mode at Maximum Load |
|-------------------------------------|----------------------|----------------------|------------------------|-------------|---|
| BRG-2585 | 1/2" EHS G.S. | 26,900 | 29,379 | 109 | Strand broke mid span. No slip from either dead-end. |
| | | | 29,379 | 109 | Strand broke mid span. No slip from either dead-end. |
| | | AVERAGE | 29,379 | 109 | |

Regards,

A handwritten signature in black ink that reads "Scott Sanderson". The signature is written in a cursive, flowing style.

Scott L. Sanderson

Senior Quality Engineer

RMB

cc: File 94, M. Miller

PLP.COM