FIRST ALERT®
MODEL SMI110
Single Station Smoke Alarm
Smoke Sensitivity: 1.04%/ft. obs ± 25%
WARNING!
ALARM IS SEALED WITH NO SERVICEABLE PARTS. BATTERY IS NOT REPLACEABLE. MAINTENANCE AND TESTING MUST BE PERFORMED AS INDICATED BELOW. CONSTANT USE AT HIGH OR LOW TEMPERATE OR HIGH HUMIDITY MAY REDUCE BATTERY LIFE.
IMPORTANT!
THIS SMOKE ALARM CONTAINS A MAXIMUM OF 1.0 MICROCURIES (37kBq) OF AMERICIUM 241, A RADIOACTIVE MATERIAL, DISTRIBUTED UNDER U.S. NRC LICENSE NO. 12-23809-01E AND IS MADE IN COMPLIANCE WITH U.S. NRC SAFETY CRITERIA IN 10CFR32.27. THE PURCHASER IS EXEMPT FROM ANY REGULATORY REQUIREMENTS.
MAINTENANCE:
Gently vacuum or use clean compressed air to remove accumulated dust monthly. Never use water, cleaners or solvents, since they may damage the unit. Press the test button after installation, weekly and after cleaning to check all alarm functions.
ALARM GUIDE:
3 Beeps – Smoke Alarm
3 "Chirp" every Minute – Malfunction – Replace Alarm
5 "Chirps" every Minute, 1 LED Flash – Low Battery – Replace Alarm
5 "Chirps" every Minute, 5 LED Flashes – End of Life – Replace Alarm
Green LED Flashes twice every Minute – Clean Alarm
HOW TO ACTIVATE ALARM:
1. ALIGN ALARM WITH MOUNTING BRACKET AND TURN CLOCKWISE.
2. PRESS AND HOLD TEST BUTTON TO ENSURE ALARM IS ACTIVATED.
HOW TO DEACTIVATE ALARM:
ONCE DEACTIVATED THE ALARM CANNOT BE REACTIVATED AND MUST BE REPLACED. TO DEACTIVATE BATTERY, BREAK AWAY TAB AND MOVE SWITCH TO DEACTIVATE POSITION.
Manufactured
Installed On _____
Replace By _____
REPLACE ALARM 10 YEARS AFTER INSTALLATION
Conforms to UL STD 217
Helps reduce cooking nuisance alarms
ETL LISTED US
Intertek
3055574
IONIZATION
Follow and retain user's manual
Customer Service Team: 1-800-323-9005
Resideo Technologies, Inc.
and its Affiliates
1301 Joe Battle
El Paso, TX, 79936 USA
Made in Mexico
DEACTIVATE
firstalert.com
N04-174652-174652