

## BUILDING MANAGEMENT SYSTEM BACnet AND MODBUS INTERFACE


Introducing the BMS Gateway for control of A. O. Smith Water Heaters

### CONNECT YOUR A. O. SMITH WATER HEATER TO YOUR BUILDING MANAGEMENT SYSTEM USING THE BMS GATEWAY

- Works with 400/450 Series Cyclone (BTH, BTHL, BTX-100, BTXL-100)
- Use the BMS Gateway to enable/disable the water heater (when used with building management system)
- Change temperature set points and differentials
- BACnet and Modbus
- All-in-one serial and Ethernet module
- Power supplied by the TRC (Temperature Regulation Control)
- Configure protocols, network characteristics, and client/server object definitions
- Graphically interact with the internal database in real-time via Ethernet connection
- Update Firmware

Kit Part #	Connection Type
100378810	Serial or RS-485*

\*Cable to be field supplied



### BMS GATEWAY

One unit needed per water heater