

Aeroseal, LLC
a JMD, Inc Company
7989 S. Suburban Road
Centerville, OH 45458



March 15, 2018

RE: Air Duct Disinfection Procedure For Aeroseal Sealant

The following products are approved for disinfecting air ducts sealed with Aeroseal sealant.

Brand Name	Concentration	Maximum exposure
Melsept SF	2%	240 minutes
Incidin Plus	8%	240 minutes