

Material Outgassing Certificate

Hereby, we confirm that the product:

Aeroseal Duct Seal LT

provided by:
Exentec U.S., Inc.
5250 E Franklin Road, Ste.
104
USA Nampa 83687

was tested according to VDI 2083 Part 17 and to the standard outgassing procedure of Exentec.

The tested product meets the acceptance criteria of Exentec at 90°C and is recommended for usage in clean areas as follows:

- in the cleanroom for coverage >50% of the net cleanroom area
- and
- in mini environments for coverage >50% of the bottom area.

Outgassing Results:

Test temperature	Group of contaminants	ISO-AMC Class _m (or)
22 °C	VOC	-8.7
Test temperature	Family of contaminants	[µg/g]
90 °C	TVOCs	13.18
90 °C	SVOCs	45.88
90 °C	Amines	46.04
90 °C	Organophosphates	n.d.

Detailed information can be obtained from Exentec test report number 260207ae.
This certificate is valid for three years from the date of issue.
Date of issue: 19. February 2026

Created:

Approved:

