

TEST RECORD NO. 1

SAMPLES:

At the request of the submitter, aerosol duct sealant designated as "Duct Seal LT" was submitted for evaluation for UL Certification. These duct sealant materials are intended to be designed and installed in accordance with the accompanying manufacturer's installation instructions.

The aerosol sealant used in this investigation was produced under the observation of a representative of UL LLC, in a ready-to-use form. The composition of the finished materials is of a proprietary nature. Data on the composition is on file at the Laboratories for use in the Follow-Up Service Program.

GENERAL:

The following tests were conducted in order to Certify the "DuctSeal LT" in accordance with UL Subject 1381, Outline of Investigation for Aerosol Duct Sealant", First Issue.

Test results relate only to the items tested.

Tests	UL 1381	
Test for Surface Burning Characteristics	Section 6	
Mold Growth and Humidity Test	Section 7	
Erosion Test	Section 8	
Burning Test	Section 9	
Leakage Reduction Test	Section 10	
Durability Test	Section 11	

Test Record Summary:

The results of this investigation, including construction review and testing, indicate that the product evaluated complies with the applicable requirements in the 1st Edition of UL Subject 1381, "Outline of Investigation for Aerosol Duct Sealant", dated August 27, 2013, and therefore, such product is judged eligible to bear UL's Mark as described on the Conclusion Page of this Report.

Test Record No. 1 By:

Reviewed By:



Jamila Shawon
Staff Engineer
Built Environment



Dwayne Sloan
Principal Engineer
Built Environment

Any information and documentation provided to you involving UL Mark services are provided on behalf of Underwriters Laboratories Inc. (UL) or any authorized licensee of UL.

CONCLUSION

Samples of the product covered by this Report have been found to comply with the requirements covering the category and the product is found to comply with UL's applicable requirements. The description and test result in this Report are only applicable to the sample(s) investigated by UL and does not signify UL certification or that the product(s) described are covered under UL's Follow-Up Service Program. When covered under UL's Follow-Up Service Program, the manufacturer is authorized to use the UL Certification Mark on such products which comply with UL's Follow-Up Service Procedure and any other application requirements of UL LLC. The Certification Mark of UL LLC on the product, or the UL symbol on the product and the Certification Mark on the smallest unit container in which the product is packaged, is the only method to identify products investigated by UL to published requirements and manufactured under UL's Certification and Follow-Up Service.

This Report is intended solely for the use of UL and the Applicant for establishment of UL certification coverage of the product under UL's Follow-Up Service. UL retains all rights, title and interest (including exclusive ownership) in this Report and all copyright therein. Unless expressly authorized in writing by UL, the Applicant shall not disclose or otherwise distribute this Report or its contents to any third party or use this Report for any purpose other than to establish UL certification and become eligible for Follow-Up Service for the product(s) described in this Report. Any other use of this Report including without limitation, evaluation or certification by a party other than UL unless part of a certification scheme, is prohibited and renders the Report null and void. UL shall not incur any obligation or liability for any loss, expense, or punitive damages, arising out of or in connection with the use or reliance upon the contents of this Report to anyone other than the Applicant as provided in the agreement between UL and Applicant. Any use or reference to UL's name or certification mark(s) by anyone other than the Applicant in accordance with the agreement is prohibited without the express written approval of UL. Any information and documentation involving UL Mark services are provided on behalf of UL LLC(UL) or any authorized licensee of UL. UL shall not otherwise be responsible to anyone for the use of or reliance upon the contents of this Report.

Report by:

Jamila Shawon
Staff Engineer
Built Environment

Reviewed by:

Dwayne Sloan
Principal Engineer
Built Environment