

Fire Door Compliance to Codes and Standards

Forte™ Opening Solutions's fire rated doors have been tested and certified for compliance to the applicable requirements of UL 10b, UL 10c, NFPA 252, and CAN4 S104.

These fire resistance ratings are listed and labeled under third party certification through Intertek Testing Services and Underwriters Laboratories. The doors bear a marking of the third party certifying agency as well as an indication of the period of fire resistance duration. Doors as marked are listed and labeled fire resistant opening protectives meeting the requirements of NFPA 80 and NFPA 101.